

2019 Draft Integrated Resource Plan

{ Entergy Louisiana, LLC. }

PUBLIC VERSION



Contents

Introduction	5
Executive Summary	6
Statement of Purpose	6
Background and Key Considerations	6
The Industry Condition	7
<i>Changing Customer Preferences.....</i>	<i>8</i>
<i>Technological Advancements</i>	<i>8</i>
<i>Utility Actions.....</i>	<i>8</i>
<i>Customer Value.....</i>	<i>8</i>
Primary Planning Objectives	9
<i>Guiding Principles</i>	<i>9</i>
Resource Adequacy and Planning Reserve Requirements	9
Current Fleet and Projected Needs	10
<i>Current Fleet</i>	<i>10</i>
<i>Projected Needs.....</i>	<i>10</i>
Assumptions and Assessments	11
Portfolio Design and Analytics	13
The Path Forward (Action Plan)	13
The Industry Condition and ELL’s Planning Framework	15
Utility Actions.....	15
Customer Preferences	16
Advancing Technology	16
Utility Actions.....	17
Increased Customer Value	17
Primary Planning Objectives	17
Participation in MISO	18
Transmission Planning	19
<i>Integration of Transmission and Resource Planning.....</i>	<i>19</i>
<i>MISO Resource Adequacy Requirements.....</i>	<i>20</i>
<i>Long-Term Planning Reserve Margin Targets.....</i>	<i>21</i>
Current Fleet and Projected Needs	22
Current Fleet	22
Existing Fleet Deactivation Assumptions	23
Load Forecasting Methodology	25
<i>Sales Forecasting</i>	<i>26</i>

(Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan)

<i>Load Forecasting</i>	27
Resource Portfolio Needs	27
<i>Long-term Capacity Considerations</i>	27
<i>ELL’s Expected Energy Coverage</i>	28
<i>ELL’s Planning Region Needs</i>	29
<i>Combustion Turbine Based Technology</i>	31
<i>Environmental Considerations of the Existing Fleet</i>	32
Summary of Types of Resources Needed	32
Assumptions	34
Supply Alternatives to Meet ELL Resource Needs	34
<i>Technology Assessment</i>	34
<i>Renewables (Solar PV and Wind)</i>	36
<i>Energy Storage Systems</i>	39
<i>Demand-Side Alternatives</i>	40
<i>Energy Efficiency</i>	40
<i>Demand Response</i>	42
<i>Summary of Emerging Supply Trends and Implications</i>	43
Natural Gas Price Forecast	43
Portfolio Design Analytics	46
Futures	46
<i>Future 1: Progression Towards Resource Mix</i>	47
<i>Future 2: Policy Reversion</i>	47
<i>Future 3: Decentralized Focus</i>	47
<i>Future 4: Economic Growth with Emphasis on Renewables</i>	47
<i>Market Modeling</i>	47
Portfolio Design	48
<i>Solar Capacity Credit Modeling</i>	48
<i>Portfolio Results</i>	49
Discussion of Results	54
Assessment of Risks	56
<i>Cost as Measured by Expected Value</i>	56
<i>Risk as Measured by the Risk Premium</i>	57
<i>Cost/Risk Tradeoff and Conclusions</i>	57
The Path Forward (Action Plan)	60
Integration of More Modular Supply	60
Renewable Energy Pricing Tariff	60
Battery Storage	61
Demand Side Management (DSM) and Demand Response Tariffs	61
Growth and Reliability Study	61

Appendices

Appendix A

Actual Historic Load and Load Forecast

Appendix B

Response to Stakeholder Comments

Appendix C

Total Supply Cost

Appendix D

Financing Assumptions

Appendix E

DSM Selections by Program

Introduction

The electric grid provides the foundation upon which a strong Louisiana economy is built. Under the guidance and authority of the Louisiana Public Service Commission (“LPSC” or “Commission”) and the rules that it has put in place, Louisiana has the lowest total retail prices in the country¹ with ELL’s own rates being at or near the lowest within the State. Attracted by Louisiana’s natural resources and infrastructure, including low electricity prices and reliable power, billions of dollars of infrastructure have been invested in the State creating thousands of jobs for Louisiana residents. Louisiana has a strong foundation, and Entergy Louisiana, LLC (“ELL” or the “Company”) seeks to fortify and grow that foundation.

Vital to Louisiana’s growing economy is the assurance that utility resources and infrastructure are in place to reliably meet the needs of existing and new customers. ELL supports continued growth in our State through its continued investment in the State which allows us to power the lives of our customers with clean, affordable, and reliable electricity. The reliability of the electric system depends on long-term resource planning and Commission oversight. This Integrated Resource Plan (“IRP”) is a product of a dynamic, ongoing process and this report provides a touchstone for this process.

Since joining the Midcontinent Independent System Operator, Inc (“MISO”) in December 2013, ELL, with approval from the Commission, has added or plans to add over 2.9 GW of new generation in the State. This investment of more than \$2.5 billion in new generation is needed to reliably serve Louisiana customers and support \$101B of new capital investment and over 16,300 new jobs in our territory, based on projects announced since 2013. This growth, in turn, leads to innumerable improvements in Louisiana communities including increased investment in our schools, streets, parks, and other resources that enhance the daily lives of Louisianans.

Participation in MISO has brought tremendous value to Louisiana customers over the last five years. ELL has estimated approximately \$95million in savings per year since joining MISO as a result of lower reserve margins and MISO’s economic dispatch of generation through its energy market. MISO, however, has no responsibility to provide or build generating capacity, and its capacity market, which is limited-term in nature, is not structured to cover the full cost of adding new generation. The MISO annual capacity market provides a mechanism for load serving entities to purchase or sell excess capacity on a limited-term basis; it is not a source of long-term capacity. Rather, MISO relies on its load serving entities (like ELL), under the regulation of state commissions (like the LPSC), to meet customer needs and ensure a reliable system. Those load serving entities do so through prudent long term resource planning, the type of planning ELL presents to the Commission in this report.

¹ Based on Form EIA-861M data from the U.S Energy Information Administration (“EIA”), Louisiana had the lowest average retail rates in the country in 2016 and 2017 and is on track to maintain that position in 2018. See EIA “Form EAI-861M (formerly EIA-826) detailed data,” which can be accessed at <https://www.eia.gov/electricity/data/eia861m/>.

Executive Summary

Statement of Purpose

This Draft IRP Report, prepared in accordance with the rules promulgated by the Louisiana Public Service Commission,² describes the long-term resource planning of ELL for the period 2019-2038. The IRP provides a holistic look at considerations in designing and leveraging a forward-thinking portfolio of resources to meet ELL customers' energy needs. The IRP outlines the current landscape and provides a path forward for ELL so that ELL can continue to power homes, businesses, and communities reliably and cost effectively, while preparing for the challenges and opportunities that lie ahead.

ELL takes a customer-centric approach to long-term planning. The considerations detailed in the following pages are focused on meeting the ever-changing supply needs of ELL's customers. ELL seeks to meet those needs through its IRP strategy, which ensures that it is making the necessary decisions to continue to enhance reliability and affordability while mitigating risks. This approach also provides the flexibility ELL requires to respond and adapt to a constantly shifting utility landscape.

Background and Key Considerations

Since submitting its last IRP, ELL has worked towards executing its action plan to support ongoing planning objectives and modernizing its fleet to support existing customers and load growth in the area served by ELL, specifically industrial growth in southern Louisiana. ELL has responded to this by moving forward with adding 2.2 gigawatts ("GW") of efficient, reliable gas-fired generation within historically constrained areas of ELL's footprint. The industrial sector is continuing to experience growth and is moving forward with a number of projects, including new projects and expansions of existing facilities.

Table 1: ELL's Planned New Resource Additions

ELL'S Planned New Resource Additions	MW	COD	Planning Area
St. Charles Power Station ("SCPS")	923	2019	Amite South
Lake Charles Power Station ("LCPS")	924	2020	WOTAB
Washington Parish Energy Center ("WPEC")	363	2021	Amite South
Total	2,210		

Additionally, ELL has executed Purchased Power Agreements ("PPAs") on almost 1 GW of combined cycle gas turbine ("CCGT") capacity and a 50 megawatt ("MW") solar photovoltaic resource – the largest of its kind for the Company and the state of Louisiana. These additions, along with continued investment in ELL's transmission infrastructure, have allowed ELL to make significant progress towards decreased reliance on less efficient generation. In total, ELL assumes 5.8 GW of generation is to be deactivated over the 20-year planning horizon. Of this amount, 3.1 GW is sourced from legacy gas units, which are currently over the age of 40. These resources are relied upon to support transmission reliability and to serve load within the Planning Areas shown in Figure 1, below, that have transmission import constraints.

² See, LPSC Corrected General Order No. R-30021, dated April 20, 2012 (*In re: Development and Implementation of Rule for Integrated Resource Planning for Electric Utilities*).

Within ELL’s service area there is expected significant load growth from new and existing large industrial customers. Constrained areas (“Load Pockets”), such as WOTAB (West of the Atchafalaya Basin) and Amite South, continue to grow contributing to the need for reliable generation within the load pockets. Flexibility will be required in resource planning as:

- ELL’s customer’s load shapes continue to change due to differing use patterns and preferences, and
- ELL continues to see the potential for block load additions in conjunction with ongoing economic development in the region




Figure 1: Outline of ELL Planning Areas

Industrial growth continues in Louisiana, and ELL sees the potential for several GW’s of additional industrial demand developing in its service area beyond what is incorporated in the 2019 ELL IRP analytics. This growth is occurring at a time when most states are seeing flat to negative load growth and provides an opportunity, not just for ELL customers, but for the state as a whole. ELL is committed to helping Louisiana capitalize on these growth opportunities through responsible long term resource planning which provides customers with clean, affordable power while improving system reliability for the benefit of all customers. ELL will continue to monitor these projects and adjust the forecast as necessary to provide a capacity and energy demand outlook based on the best available information at the time.

ELL’s IRP is based on the best information available at the time of submittal; however, any insights taken from the IRP analytics must be made in light of the current load forecast, which could change with block load additions. As discussed throughout the IRP, subsequent planning flexibility is necessary to respond to changing conditions. Given the potential for legacy steam unit deactivations during the planning horizon and the potential load growth within southern portions of Louisiana, sound, proactive planning is required to address ongoing reliability requirements and needed flexibility throughout the planning horizon.

The Industry Condition

Gas-fired generation is expected to continue to be an important component of a diverse generation portfolio. However, ELL recognizes that the way its customers use and consume energy is changing especially in the residential and commercial

sectors, so the way it plans for, produces, and delivers the power they rely on must evolve as well. ELL strives to have a planning process that provides for the flexibility needed to better respond to this constantly evolving environment. Below are additional considerations, changes, and opportunities that help drive ELL's IRP strategy.

Changing Customer Preferences

The evolution and adoption of customer-centric technology and services, both in and out of the traditional utility construct, have created a shift in customer preferences and expectations—both in terms of how the power they use is generated, and the services and offerings they value from utility companies.

Today's energy customers seek more options in the generation and delivery of energy, including how they interact with, understand, and manage their own energy use, as well as the actual sources from which their energy is derived. Increasingly, customers are becoming more interested in getting their power from cleaner, more sustainable sources of energy, including natural gas, nuclear, and renewables like wind and solar.

ELL is focused on achieving a better understanding of these changing customer preferences so that they can be taken into account in the IRP process. This will allow ELL to:

- **Develop a comprehensive outlook on the future utility environment** so it can more effectively anticipate and plan for the future energy needs of its customers and region.
- **Incorporate new, smart technologies and advanced analytics** to better assess where expanding resource alternatives can be leveraged, and plan for improvements and enhancements to the electrical grid.
- **Continue to integrate and offer the innovative products and services** its customers want and expect.

Technological Advancements

Technological advancements provide the energy industry increased alternative pathways to plan for and meet customer's energy needs. From energy production and generation, to storage and delivery, these innovations are helping strengthen reliability and increase affordability for the homes, businesses, industries, and communities ELL serves. These new technologies also support the continued development and expansion of sustainability efforts while addressing ELL's long-term planning objectives, outlined in further detail below.

The development of an Integrated Grid, which would include ELL's Advanced Metering System, as just one example, is enabling the entire utility industry to better understand the new, changing ways in which customers are using energy. That allows energy companies to make more informed decisions and provide tailored customer solutions through enhancements to the electric infrastructure, the adoption of new products and services, and more.

Utility Actions

ELL understands that its customers' needs and expectations are changing, and these changes will help inform the IRP process as well as ELL's approach to customer service. Accordingly, ELL is evaluating and incorporating new, customer-centric technology and designing an energy portfolio that leverages a more diverse mix of energy resources—including a greater reliance on renewable and clean energy sources—to adapt to the changing needs of customers while keeping affordability and reliability top of mind for the customers ELL serves. ELL sees opportunity in providing a portfolio of efficient generation for the increased electrification of other industry sectors, including transportation, which will add to regional sustainability.

Customer Value

Taken together, the changing customer preferences, technological advancements, and utility actions described above coalesce to provide increased value for ELL's customers. By combining a more thorough understanding of what today's energy customers want from their utility with a comprehensive, forward-thinking IRP process, ELL can deliver the services

and products customers desire while maintaining reliable, cost effective service.

Primary Planning Objectives

Throughout the IRP process, and in the normal course of business, ELL is seeking to identify, deploy, and integrate the right mix of technology, resources, and products and services for its customers. While the scope and nature of the utility industry must always be evolving in response to the aforementioned factors, ELL's primary objectives in the planning process remain the same:

- **To serve customers' power needs reliably**, helping to meet the energy needs of the homes, businesses, and communities ELL serves now and in the future.
- **To reliably provide power at the lowest reasonable supply cost**, by pursuing a diverse mix of energy resources, new generation techniques, and customer-centric technological innovations.
- **To mitigate exposure to risks that may affect customer cost or reliability**, keeping energy as affordably priced and reliable for ELL customers as possible.

Guiding Principles

ELL's planning process is guided by the following principles to support planning objectives:

- **Capacity** - Provide adequate capacity to meet customer needs.
- **Base Load Production Cost** - Meet base load requirements to keep costs stable.
- **Load Following Production Cost** - Respond to the varying needs of customers based on a number of factors.
- **Modern Portfolio** – Leverage ELL's modern, efficient generation while evaluating economics and reliability associated with less efficient legacy units.
- **Price Stability** - Mitigate exposure to price volatility.
- **Supply Diversity** - Diversify technology, location, capital commitments, and supply channels.
- **In-Region Resources** - Leverage a variety of in-region resources to meet customers' needs reliably and affordably.

Resource Adequacy and Planning Reserve Requirements

ELL is responsible for planning and maintaining a diverse energy resource portfolio that meets customers' power needs consistent with reliability, which requires maintaining the right types and amounts of generating capacity. With respect to the amount of capacity this requires, ELL takes into consideration two primary factors:

1. **MISO Resource Adequacy requirements.** MISO Resource Adequacy requirements are set annually and apply only to the subsequent planning year (defined as a one-year period beginning every June 1st). While this process establishes minimum requirements that must be met in the short-term and provides additional information on ELL capacity needs, it does not provide an appropriate basis for determining long-term resource needs. Also, relying solely on this near-term outlook for planning purposes unnecessarily exposes ELL's customers to reliability and economic risk.
2. **Long-term planning reserve margin targets.** Because of the limited-term focus of MISO Resource Adequacy requirements, ELL plans its portfolio to meet projected peak load, plus a 12 percent planning reserve margin, based on installed capacity. This approach ensures that ELL is able to maintain reliability for its customers even during unplanned events, like generating unit outages and extreme weather, over the long-term planning horizon, while still benefitting from participation in MISO's broader energy markets. This long-term planning approach (as opposed to relying heavily on MISO's capacity and energy markets) not only helps reduce unnecessary reliability and economic risk to customers but also allows ELL to be more agile in serving potential load growth and

addressing resource needs as existing generation reaches the end of their useful life.

Through this two pronged approach, ELL is able to meet its capacity needs reliably while protecting customers against extreme price fluctuations and uncertainty.

Current Fleet and Projected Needs

Current Fleet

In recent history, ELL has been successful in transforming its portfolio with reliable, efficient Combustion Turbine (“CT”) and CCGT capacity to meet its supply needs. By 2021, ELL expects this type of technology to account for over 50% of owned and contracted capacity, replacing less efficient legacy gas units.




Figure 2: ELL's Evolving Portfolio

ELL's 2019 Integrated Resource Plan analytics will help explore the right types of resources to replace deactivating generation and meet ELL's growing and changing load. Additionally, the economics of non-traditional supply (i.e. energy storage, renewables) and demand side alternatives will be explored to more fully understand the benefits of a diverse mix of fuel and technology types.

Projected Needs

A number of factors have been considered and evaluated in order to understand and determine ELL's supply needs:

- **Long-Term Capacity Requirements** - Given the evolving resource mix within ELL's portfolio, ELL will need new generating capacity over the course of the 20-year IRP planning period. Taking deactivation assumptions, expected load growth, and units recently certified by the Commission into account, ELL's long-term deficit is expected to approach 7 GW³ by the end of the planning horizon.
- **Energy Requirements** - In addition to capacity requirements, ELL regularly examines its current and projected fleet to ensure it can effectively meet its energy requirements. Understanding current energy sufficiency also helps

³ Value does not include several GW of potential block load additions that are currently not incorporated into the 2019 ELL IRP analytics.

inform the future portfolio design. As resources deactivate and ELL's capacity requirements increase, ELL will look to balance energy producing and grid-balancing supply options to effectively and efficiently meet customer requirements.

- **Planning Region Needs-** Amite South is a load pocket within ELL's service area that contains a high amount of existing and potential high load factor industrial load. The area regularly relies on local generation as well as imports to serve peak load and transmission requirements. Further, a large portion of ELL's generation, specifically legacy assets, is located in the area. Transmission and generation requirements will continue to be evaluated to support the reliability of the planning regions as load grows and infrastructure ages.
- **Environmental Regulations** - Fossil fueled generation could be subject to future federal and state plans and regulations developed to meet the requirements of the federal Regional Haze Rule and other policies. As explained below, ELL considers future carbon emission pricing scenarios in its analysis. ELL's long-term planning process and the evaluation outlined in this IRP help inform how ELL will meet its future capacity and energy requirements.

Assumptions and Assessments

In designing ELL's 2019 IRP, a number of factors and assumptions were used to guide the portfolio design analysis and strategy, including:

- **Analyzing the technological landscape to identify potential supply-side generation solutions** that could help ELL serve customers' needs reliably and at the lowest reasonable cost, including existing and emerging natural gas, renewable, and energy storage technologies. ELL's technology assessment for the 2019 IRP seeks to explore in greater detail the challenges and opportunities of various generation alternatives as well as corresponding cost information to consider when designing the optimal resource portfolio to meet the capacity needs of its customers.
- **Ever-advancing technology provides new opportunities to meet customers' needs reliably and affordably.** Renewable energy resources are becoming increasingly economic alternatives with historically declining costs as illustrated in Figure 3 below, and these costs are expected to continue to improve throughout the planning horizon.




Figure 3: Utility Scale P.V., One-Axis Tracker⁴

With an increased deployment of intermittent generation, the value and necessity of flexible, diverse supply alternatives and smaller, more modular resources, such as battery storage devices, increases in order to provide opportunities to reduce risk and better address locational and site specific reliability requirements while continuing to support overall grid reliability. Costs of energy storage resources have been observed to decline significantly in recent history, shown in the chart below, and are expected to continue to decline over the planning horizon.




Figure 4: Lithium Ion Battery Costs⁵

⁴ Data adapted from National Renewable Energy Laboratory (“NREL”) U.S. Solar Photovoltaic System Cost Benchmark, Q1 2017.

⁵ Source: Bloomberg New Energy Finance (“BNEF”).

- **Identifying and incorporating effects of potential cost effective demand-side management programs.** For the 2019 IRP, ELL engaged ICF to produce a DSM potential study that includes both energy efficiency (“EE”) and demand response (“DR”) offerings. The study considered EE programs including those administered by ELL’s Quick Start Phase I Program Year 2 (“PY2”) (referred to as “Current Programs”), an expansion of those programs, and new offerings. For demand response, a variety of offerings were included related to price response and load response programs. It should be noted that the ICF DR potential study relied on time of use for DR savings, noting that the infrastructure for dynamic pricing alternatives was not in place. However, with the deployment of AMI, ELL will be well positioned to offer dynamic pricing which may be a better alternative for sending appropriate price signals for DR than traditional time of use rate structures which require customers to shift consumption over long periods of time in order to avoid on peak pricing. In fact, residential TOU options at other Entergy operating companies have had limited interest and very low enrollment. Overall, ELL believes that dynamic pricing alternatives better align with customers’ evolving expectations because they are less invasive on an everyday basis than TOU rate structures, in helping customers manage their bills.
- **Preparing a natural gas price forecast to serve as a model for future natural gas pricing** based on current market expectations. Due to limitations in natural gas forecasting as well as overall uncertainty in the natural gas market, ELL presents three scenarios for natural gas prices.
- **Considering the potential for carbon regulation for the energy sector**, including identifying three potential scenarios for how the timing, design, and outcome of such regulation may result in the cost to operate carbon-emitting generation.
- **Developing a 20-year, hour-by-hour load forecast, taking into account a wide range of factors** including, but not limited to: economic growth and activity, developments in energy efficiency technology, changes in customer use and consumption, and the potential adoption of distributed generation technologies.

Portfolio Design and Analytics

ELL used a futures-driven scenario approach to guide the IRP process and strategy, through which it analyzed the total supply cost of four different resource portfolios under these different futures. The futures included unique attributes and assumptions in order to provide a range of market drivers and outcomes to analyze the portfolios against. This approach helps form the basis of understanding potential benefits and risk to ELL’s customers derived from the attributes of each portfolio.

As a result of the portfolio analytics, ELL observed that a combination of CCGTs, peaking gas resources, and solar has the potential to meet planning objectives of cost, risk, and reliability. However, more detailed analyses will be required as ELL executes on supply alternatives. These analyses will need to account for current market conditions, availability of supply alternatives, customer preferences, feasibility and practicality of certain supply options, ELL’s energy needs, local reliability criteria, potential environmental regulation and carbon emissions pricing, and transmission planning requirements.

The Path Forward (Action Plan)

ELL considers a number of factors when designing an IRP strategy that will enable the company to continue serving customers’ power needs as reliably and affordably as possible. ELL believes that the following actions are important as it pursues a path forward to a strong energy future for ELL customers:

1. **Legacy Generation Economic Study** - As a part of its robust and iterative long-term planning processes, the Company continually monitors and studies the condition of units, market conditions, and economics to evaluate whether legacy units are candidates for deactivation or retirement. Consistent with the LPSC directive from the February 21, 2018

open session, ELL will conduct a comprehensive evaluation to assess the continued operations and role of its legacy fleet.⁶ The study will consider the reliability implications of future unit deactivation and retirements and will provide additional insight into the transmission and generation support needed within the Amite South region given the current generation fleet, existing load, and potential load growth within the region.

2. **Integration of more modular supply** - As customers are increasingly interested in sustainable energy generation and costs for solar generation continue to decline, ELL continues to plan for increased investments in, and development of, its renewable energy resources and generation. This includes the potential to bring more economic solar generation online in the coming years to support ELL's planning objectives.
3. **Renewable Energy Pricing Tariff** - In conjunction with its first utility-scale solar resource, ELL is seeking Commission authorization of an Experimental Renewable Option and Experimental Renewable Option Rate Schedule, which provides pricing that is tied directly to renewable generation.
4. **Battery Storage** - Battery storage has the potential to provide an array of benefits, including the ability to store energy for later use and delivery, rapid construction, a significantly smaller footprint that allows for more flexible siting and greater portability to enable redeployment in different areas. Given the implications such technology has for the utility industry and with the expectations that costs will decline, continuing to explore opportunities to expand upon and develop this technology will be critical.
5. **Demand Side Management ("DSM") and Demand Response tariffs** - The IRP analytics indicated the value DSM may bring ELL's customers. ELL intends to conduct more detailed analysis of those Demand Response ("DR") and Energy Efficiency ("EE") programs that proved to be economic in its modeled portfolio results. In addition to the programs shown to be economic in the IRP analysis, and in response to customer feedback in this IRP cycle, ELL will develop and offer new interruptible tariffs with options for participation in the MISO energy and capacity markets. The offering of these tariffs will further explore customer interest in demand response as an option for meeting the Company's capacity needs. In addition, with the deployment of AMI, ELL will explore new dynamic pricing alternatives, such as dynamic pricing which can better correlate prices with the costs of energy at different times for DR.
6. **Growth and Reliability Study** - ELL, like all LSEs within MISO, is responsible for planning and maintaining a resource portfolio to meet its customers' power needs. The Commission has acted as a steward of responsible system planning through various requirements, including but not limited to IRP requirements, periodic reporting on load forecasts, and resource certifications. ELL plans to undertake a study to evaluate load growth and unit deactivations not accounted for in the Commission's current long-term planning processes in order to measure potential impact on ELL customers and system reliability, which may affect ELL's resource needs.

⁶ http://www.lpsc.louisiana.gov/_docs/_Minutes/2.21.2018%20BE%20Minutes.pdf



Section I

The Industry Condition and ELL's Planning Framework

ELL's planning process seeks to design a portfolio of resources that reliably meets customer power needs at the lowest reasonable supply cost while considering risk. While traditional resource planning will continue, the landscape within the electric utility industry is changing and ELL is putting plans in place to provide flexibility in how to respond to the evolving environment.




Figure 5: Changes and Opportunities within the Utility Industry

Utility Actions

The scope and nature of ELL's business will and must change in response to the changing landscape. ELL's objective is to find, deploy, and integrate the right mix of technology, products, and services that provide solutions to serve the needs of its customers. ELL's planning processes and tools are evolving and will continue to evolve in order to help identify customer needs and wants, along with developing a comprehensive understanding of the various technological changes and opportunities within the utility industry. This increased understanding will enable ELL to design a portfolio of resources and services that meet customers' changing needs and wants while addressing ELL's planning objectives of cost, reliability, and risk. As knowledge and understanding increases, ELL strives to educate all stakeholders regarding these developments in order to make informed decisions, recognizing that financial investments are necessary to improving existing energy technologies and developing a portfolio of supply alternatives and products and services to meet customers' evolving expectations and needs.

Increased Customer Value

By combining an understanding of what its customers want with sound and comprehensive planning, ELL can ensure that it continues to deliver the types of services and products its customers expect while continuing to address traditional planning objectives of cost, reliability, and risk. Increasing the array of alternatives provides an opportunity to better meet planning principles by providing a diverse portfolio of alternatives to meet long-term capacity, transmission, and ancillary service requirements. A diverse portfolio mitigates exposure to price volatility associated with uncertainties in fuel and purchased power costs, and risks that may occur through a concentration of portfolio attributes such as technology, location, large capital, or supply channels. Additionally, taking advantage of increased and evolving opportunities, ELL continues its effort of modernizing its supply portfolio.

Primary Planning Objectives

While the utility environment may be changing, ELL continues to plan to accomplish three broad objectives:

- ***To serve customers' power needs reliably;***
- ***To reliably provide power at the lowest reasonable supply cost; and***
- ***To mitigate exposure to risks that may affect customer cost or reliability.***

These objectives will be achieved while considering utilization of natural resources and the effect on the environment.

Objectives are measured from a customer perspective. That is, ELL's planning process seeks to design a portfolio of resources that reliably meets customer power needs at the lowest reasonable supply cost while considering risk.

In designing a portfolio to achieve the planning objectives, the planning process is guided by the following principles:

- ***Capacity*** - Provide adequate capacity to meet customer needs measured by peak load plus a long-term planning reserve margin.
- ***Base Load Production Cost*** - Provide resources to economically meet base load requirements at reasonably stable prices.
- ***Load Following Production Cost*** - Provide economically dispatchable resources capable of responding to the varying needs of customers driven by such factors as time of use, weather, and the integration of renewable generation.
- ***Modern Portfolio*** - Leverage ELL's modern, efficient generation while evaluating economics and reliability associated with less efficient legacy units.
- ***Price Stability*** - Mitigate exposure to price volatility associated with uncertainties in fuel and purchased power costs.
- ***Supply Diversity*** - Mitigate exposure to risks that that may occur through concentration of portfolio attributes such as technology, location, large capital commitments, or supply channels.

- **In-Region Resources** - Avoid overreliance on remote resources; provide adequate amounts and types of in-region resources to meet area needs reliably at a reasonable cost.

Participation in MISO

ELL has been a market participant in the MISO Regional Transmission Organization (“RTO”) since December 19, 2013. MISO is a non-profit, member-based organization, which exists to provide an independent platform for efficient regional energy markets. MISO conducts transmission planning and manages buying and selling of wholesale electricity across 15 U.S. states and the Canadian province of Manitoba.

As shown below, ELL is located within Local Resource Zone (“LRZ”) 9 of the MISO footprint.




Figure 7: LRZ 9 within MISO

As a MISO member, ELL has access to a large, structured market that enhances the resource alternatives available to meet customers’ near-term power needs. Over the long term, the availability and price of power in the MISO market affects ELL’s resource strategy and portfolio design. Additionally, ELL retains responsibility for providing safe and reliable service to its customers. Thus, the 2019 ELL IRP is designed to help ensure development of a long-term integrated resource plan for ELL that reflects that responsibility and balances the objective of minimizing the cost of service while considering factors that affect risk and reliability.

Transmission Planning

The Company's transmission planning ensures that the transmission system:

- (1) remains compliant with applicable North American Electric Reliability Corporation ("NERC") standards and the company's related local planning criteria, and
- (2) is designed to efficiently deliver energy to end-use customers at a reasonable cost. Since joining MISO, ELL plans its transmission system in accordance with the MISO Tariff.

Expansion of, and enhancements to, transmission facilities must be planned well in advance of the need for such improvements given that regulatory approvals, right-of-way acquisition, and construction can take years to complete. Advanced planning requires that computer models be used to evaluate the transmission system in future years, taking into account the planned uses of the system, generation and load forecasts, and planned transmission facilities. On an annual basis, the Company's Transmission Planning Group performs analyses to determine the reliability and economic performance needs of ELL's portion of the interconnected transmission system. The projects developed are included in the Long Term Transmission Plan ("LTTP") for submission to the MISO Transmission Expansion Planning ("MTEP") process as part of a bottom-up planning process for MISO's consideration and review. The LTTP consists of transmission projects planned to be in-service in an ensuing 10-year planning period. The projects included in the LTTP serve several purposes: to serve specific customer needs, to provide economic benefit to customers, to meet NERC transmission planning reliability standards, to facilitate incremental load additions, and to enable transmission service to be sold and generators to interconnect to the electric grid.

With regard to transmission planning aimed at providing economic benefit to customers, ELL has and will continue to actively engage in MISO's top-down regional economic planning process, referred to as the Market Congestion Planning Study ("MCPS"), which is a part of the MTEP process. MISO's MCPS relies on the input of transmission owners and other stakeholders, both with regard to the assumptions and scenarios utilized in the analysis and identification of proposed projects intended to bring economic value to customers. Based on this stakeholder input, MISO evaluates the economic benefits of the submitted transmission projects while ensuring continued reliability of the system. The intended result of the MCPS is a project, or set of projects, determined to be economically beneficial to customers, which is submitted to the MISO Board of Directors for approval. MISO typically recommends transmission projects found to result in economic benefits to the MISO Board for their approval in December of the MTEP year.

Details of the LTTP projects can be found in the current and past MISO MTEP reports, which are publicly available at www.misoenergy.org/planning/transmission-studies-and-reports

Integration of Transmission and Resource Planning

The availability and location of current and future generation on the transmission system can have a significant impact to the long-term transmission plan and requirements for meeting NERC reliability standards and efficiently delivering energy to customers at a reasonable cost. Like transmission, new generation must be planned well in advance, and due to the interrelationship of generation and transmission planning, looking far enough into the future and addressing potential supply needs is critical in meeting ELL's planning objectives of cost, reliability, and risk. As part of ELL's ongoing planning process, ELL seeks to support transmission and capacity requirements through siting needed generation in locations that support and are supported by the transmission infrastructure. An example of ELL's diligence in siting generation to support the transmission system is in the planning and execution of LCPS and SCPS.

Stability of the transmission system is, in large part, correlated to the inertia of the rotors spinning within operating generation and the real and reactive power produced. In concert, these services allow the transmission system to resist

changes to system frequency and maintain steady operating characteristics. This is of particular importance when serving large motors and industrial loads, a large component of ELL's customers. Although inverter-based technology such as solar PV does not inherently provide these services in the same manner as spinning generation, these resources can still provide benefits to the region's energy mix. Going forward, ELL will have to balance the need for conventional generation to provide adequate reliability for its industrial customers while pursuing transmission solutions and inverter-based technology when economic, capable of enhancing reliability, and/or when appropriate for meeting its customers' preferences.

The continued evaluation and condition of ELL's legacy gas-fired generation, which will be discussed further later in the document, must be taken into account to support integrated generation and transmission planning. ELL's aging legacy fleet has the potential and expectation of deactivating during the planning horizon, which will have an impact on transmission reliability requirements without apposite replacement generation.

ELL's Integrated Resource Planning models used in the analysis described herein does not consider transmission as an alternative to generation. Transmission does not provide generating capacity and energy needed to serve ELL's customers. ELL's resource portfolio is based primarily on meeting projected capacity and energy needs as are prescribed by ELL's guiding principles. While the implementation of a sound transmission plan is necessary to ensure reliability and can facilitate the efficient flow of energy within a system, it does not address capacity needs. Other analyses, which are part of ongoing planning processes, such as for the siting of specific future generation resources, will take into account transmission planning by applying the transmission topology, including approved MISO MTEP projects.

Resource Adequacy and Planning Reserve Requirements

As a load serving entity ("LSE") within MISO, ELL is responsible for planning and maintaining a resource portfolio to meet its customers' power needs. To meet its customers' needs, ELL must maintain the right type and amount of capacity in its portfolio. With respect to the amount of capacity, two considerations are relevant: **1) MISO Resource Adequacy Requirements**; and **2) Long-Term Planning Reserve Margin Targets**.

MISO Resource Adequacy Requirements

Resource Adequacy is the process by which MISO obligates participating LSEs to procure sufficient capacity, through the procurement of zonal resource credits ("ZRC") equal to their Planning Reserve Margin Requirement ("PRMR") in order to ensure regional reliability. ZRCs are provided by both supply-side generation and demand side alternatives. An LSE's PRMR is based on its forecasted peak load coincident with MISO's forecasted peak load, plus a planning reserve margin established by MISO annually for the MISO footprint.

Under MISO's Resource Adequacy process, the planning reserve margin is determined annually by November 1st prior to the upcoming planning year (June - May). Additionally, through MISO's annual Resource Adequacy process, MISO determines the annual capacity needs for a particular region or LRZ based on load requirements, capability of the existing generation, and import capability of the LRZ. Those generation needs are articulated through a Local Clearing Requirement for the LRZ for each Planning Year.

At present, the MISO Resource Adequacy process is a short-term construct. Requirements are set annually and apply only to the next year. Similarly, the cost of planning resource credits, as determined annually through the MISO auction process, apply only to the forthcoming year. Both the level of required ZRCs and the cost of those ZRCs are subject to change from year to year. In particular, the cost of ZRCs can change quickly as a result of, among other things, changes in bidding strategy of market participants, the availability of generation within MISO and a specific LRZ, and an LRZ's Local Clearing Requirement. As a result, although the MISO Resource Adequacy process establishes minimum requirements that must be met in the short term and are reviewed regularly as part of the resource planning process, it does not provide an appropriate basis for determining ELL's long-term resource needs. In other words, relying on the short-term market for ZRCs to meet customers' long-term power needs involves risk. A more stable basis for long-term planning is needed if ELL is to meet its long-term planning objectives.

Long-Term Planning Reserve Margin Targets

ELL plans its portfolio to meet its projected peak load, plus a 12 percent planning reserve margin, based on installed capacity. The long-term planning reserve margin is intended as a generation supply safety margin to maintain reliable service during unplanned events including, but not limited to, generating unit forced outages, extreme high temperatures, and load forecast deviations while still taking into account the advantages of participating in MISO's broader market. Moreover, a portfolio of long-term physical resources (versus relying heavily on MISO's capacity and energy markets) helps reduce unnecessary reliability and economic risk to customers and allows ELL to be more agile with potential load growth and aging infrastructure.



Section II

Current Fleet and Projected Needs

Current Fleet

ELL currently controls nearly 9 GW of generating capacity through either direct ownership or through life-of-unit contracts with affiliate Entergy Operating Companies. The table below shows ELL's supply resources by resource type measured in installed capacity with the percentage contribution to the overall portfolio.

Table 2: ELL's Resource Portfolio – Fuel Mix

ELL'S Resource Portfolio: Fuel Type	MW	%
Coal	392	4%
Nuclear	1,981	22%
CCGT	2,634	30%
CT	445	5%
Legacy Gas	3,115	35%
Load Modifying Resources	333	4%
Total	8,900	100%

Of this 8,900 MW, about a third of ELL's total capacity is derived from legacy gas units, which range in age from 43 to 52 years of service and are assumed to deactivate over the course of the IRP planning horizon.

In addition to these legacy gas assets, ELL also maintains ~400 MW of coal fired generation within the supply portfolio, from ownership shares in the Nelson 6 and Big Cajun 2 facilities, in addition to affiliate Power Purchase Agreements of Independence and White Bluff. Currently, these resources provide fuel diversity and solid fuel assurance to ELL's customers. Throughout the planning period, Nelson 6 and Big Cajun 2, Unit 3 are assumed to continue to operate. These units will continue to operate as long as operating the resources is consistent with ELL's long-term planning objectives. Independence and White Bluff are assumed to deactivate during the IRP planning period.

ELL's current portfolio by unit is shown in the table below.

Table 3: ELL's Resource Portfolio by Unit

Plant	Unit	MW	Fuel	Location	Operation Date
Acadia	2	544	Natural Gas	Acadia, LA	2002
ANO	1	22	Nuclear	Pope, AR	1974
ANO	2	26	Nuclear	Pope, AR	1980
Big Cajun 2	3	139	Coal	Pointe Coupee, LA	1983
Calcasieu	1	143	Natural Gas	Calcasieu, LA	2000
Calcasieu	2	156	Natural Gas	Calcasieu, LA	2001
Grand Gulf	-	205	Nuclear	Claiborne, MS	1985
Independence	1	7	Coal	Independence, AR	1983
Little Gypsy	2	401	Natural Gas	Saint Charles, LA	1970
Little Gypsy	3	508	Natural Gas	Saint Charles, LA	1971
Ninemile	4	669	Natural Gas	Jefferson, LA	1971
Ninemile	5	740	Natural Gas	Jefferson, LA	1973
Ninemile	6	443	Natural Gas	Jefferson, LA	2014
Ouachita	3	249	Natural Gas	Ouachita, LA	2002
Perryville	1	361	Natural Gas	Ouachita, LA	2002
Perryville	2	104	Natural Gas	Ouachita, LA	2001
Riverbend 30	-	191	Nuclear	West Feliciana, LA	1986
Riverbend 70	-	389	Nuclear	West Feliciana, LA	1986
Roy Nelson	6	221	Coal	Calcasieu, LA	1982
Sterlington 7 A	7A	46	Natural Gas	Ouachita, LA	1974
Union PB	4	494	Natural Gas	Union, AR	2003
Union PB	3	497	Natural Gas	Union, AR	2003
Waterford	3	1147	Nuclear	Saint Charles, LA	1975
Waterford	4	32	Natural Gas	Saint Charles, LA	1975
Waterford	1	399	Natural Gas	Saint Charles, LA	1985
Waterford	2	399	Natural Gas	Saint Charles, LA	2009
White Bluff	1	13	Coal	Jefferson, AR	1980
White Bluff	2	12	Coal	Jefferson, AR	1981
LMR (Load Modifying Resource)	-	333	N/A	-	
Total	-	8,900			

Existing Fleet Deactivation Assumptions

The IRP includes deactivation assumptions for existing generation in order to plan for and evaluate the best options for replacement capacity over the planning horizon. Based on current planning assumptions, during the planning period, the total net reduction in ELL's generating capacity from the anticipated unit deactivations is expected to be ~6 GW. Generally, the IRP analysis reflects generic deactivation assumptions for the generation fleet: 60 years for coal and legacy gas resources, and 30 years for combustion turbine technology (CTs and CCGTs). As resources age and assumed deactivation dates near, as equipment failures occur, or as operating performance diminishes, cross-functional teams are then assembled to evaluate whether or not to keep a particular unit in service for a specified amount of time and level of reliability. Any resulting

deviations from the generic assumptions are detailed below. These deactivation assumptions do not constitute a definitive deactivation schedule but are based upon the best available information and are used as planning tools to help to prompt cross-functional reviews and recommendations. It is not unusual for these assumptions to change over time, given the dynamic use and operating characteristics of generating resources. Some of these deactivation assumptions could accelerate as these units approach the end of their design-life.

In the near term, ELL's unit deactivation assumptions for the 2019 ELL IRP are outlined below.

Little Gypsy 2 and 3

Deactivations currently assumed for Little Gypsy 2 and 3 are 2026 and 2029 respectively. These are generic assumptions only and do not reflect unit specific analyses or decisions. As is stated above, these assumptions are reevaluated as the resources age and their conditions change.

White Bluff 1, White Bluff 2 and Independence 1

ELL currently has a life-of-unit contract with Entergy Arkansas, Inc. ("EAI") for a portion of White Bluff 1, White Bluff 2 and Independence 1 coal units. ELL assumed within its modeling an accelerated deactivation date to reflect EAI's commitment to cease to burn coal at White Bluff by 2028 and its planning assumption to cease burning coal at Independence by the end of 2030.

These assumptions are summarized in the table below.

Table 4: Near-Term Deactivation Assumptions

Plant	Unit	Assumption
Little Gypsy	2	2026
White Bluff	1	2027
White Bluff	2	2028
Little Gypsy	3	2029
Independence	1	2030

Consistent with the LPSC directive from the February 21, 2018 open session, ELL will complete a study of the economic viability of all legacy power plants. This study will be finalized no later than six months following the commercial operation date of Lake Charles Power Station. This evaluation will support the current or a change to the deactivation assumptions for ELL's legacy generation.

Load Forecasting Methodology

A wide range of factors will affect electric load in the long term, including:

- Levels of economic activity and growth;
- The potential for technological change to affect the efficiency of electric consumption;
- Potential changes in the purposes for which customers use electricity (e.g., replacement of vehicles that operate using internal combustion engines with vehicles that operate using electric motors);
- The potential adoption of end-use (behind-the-meter) self-generation technologies (e.g., rooftop solar panels); and
- The level of energy efficiency, conservation measures, and distributed generation adopted by customers.

Such factors may affect both the levels and patterns of electricity consumption in the future. Peak loads may be higher or lower than projected levels. Similarly, industrial customer load factors may be higher or lower than currently projected. Uncertainties in load levels and patterns may affect both the amount and type of resources required to efficiently meet customer needs in the future.

The long-term load forecast is an hour-by-hour, 20-year forecast of MW consumption. The preparation of the long-term load forecast involves two distinct and sequential processes: (1) electric sales forecasting and (2) load forecasting. In the first process, the monthly sales are forecasted assuming normal weather across the forecast horizon. The second process takes the monthly sales forecast and develops monthly peaks and allocates the monthly MWh to individual hourly MW based on hourly consumption profiles or shapes. These processes are discussed in more detail below.

For the 2019 IRP, three load forecasts were produced as part of the futures analytical framework:

Table 5: Load Forecasting Scenarios

Scenario	Drivers
Low	<ul style="list-style-type: none"> • Residential customer growth rate decreased by 15% and commercial customer growth rate decreased by 25% <ul style="list-style-type: none"> ○ Job growth does not materialize in the area ○ Brick and mortar retail stores continue closing in the face of online competition • Residential and Commercial Energy Efficiency increases 25% <ul style="list-style-type: none"> ○ Energy Efficiency appliance technology continues to advance ○ LED light bulbs continue to get cheaper with higher adoption ○ Commercial electricity prices increase by 10% with elasticity of -0.2 ○ Large and Small Industrial growth rates decreased by 20% • Industrial <ul style="list-style-type: none"> ○ Fewer new projects come online as well as reduced output from existing customers ○ LNG economics do not allow new export facilities to become operational ○ Customers add more cogeneration and solar to offset power consumption
Reference	<ul style="list-style-type: none"> • The nature of ELL's natural resources and tax structure created opportunities for new large and small industrial sales • Increases in heating and cooling equipment efficiency as well as LED lighting becoming more affordable and common • Use per customer declines in Residential and Commercial, partially offset by growth in customer counts
High	<ul style="list-style-type: none"> • Residential customer count growth rate increased by 25% and commercial customer count growth rate increased by 10% • Residential appliance energy efficiency decreased by 25% <ul style="list-style-type: none"> ○ LED light bulb penetration weaker than anticipated

- New administration discontinues Energy Star program used to incentivize businesses to create more efficient appliances
- Large and small industrial sales growth rates increased by 10% and realization of speculative projects

Sales Forecasting

The sales forecast is developed using a bottom-up approach by customer class – residential, commercial, large industrial, small industrial, and governmental.

The sales forecasts for the large industrial customers are developed individually and are based on a mix of historical consumption levels and information about expected future operations including outages, expansions, or contractions. Forecasts for new industrial customers are based on information from the new customer as well as expertise from Entergy’s Economic Development team. Expected MW size, operating profile, and ramp schedule are taken into account. Forecasts for new large industrials are also risk-adjusted based on the status of development.

The sales forecasts for the residential, commercial, small industrial, and governmental classes are developed individually using statistical regression software and a mix of historical data and forward-looking data. The historical data primarily includes monthly sales volumes by class and temperature data expressed as cooling degree days (“CDDs”) and heating degree days (“HDDs”). Some of the forecasts also use historical indices for elements such as population, employment, and levels of end-use consumption for things such as heating/cooling, refrigeration, and lighting. These historical data are used in econometric forecasting software called Metrix ND, which is licensed from Itron. This software is used to develop statistical relationships between historical consumption levels and weather, economic factors, and/or time periods and those relationships are applied going forward to estimates of normal weather, economic factors, and/or time periods to develop the forecast.

The sales forecasts are based on an assumption of weather being “normal” going forward. For this purpose, normal weather is defined as a 20-year average of temperatures by month. The use of 20 years strikes a reasonable balance between longer periods (30 years), which may take longer to pick up changing weather trends and shorter periods (10 years), which may not provide enough data points to smooth out volatility. The 20-year averages are built from hourly temperatures and are allocated to each calendar month based on the billing cycles for each month to ensure that the resulting averages appropriately consider the temperatures on the days when the power was consumed.

The residential and commercial forecasts also include assumptions for ELL’s DSM programs. DSM adjustments include the historical effects of DSM programs as well programs that are planned for future periods.

For example, a program from last year to encourage conversion of incandescent lighting to LED lighting is still expected to lower consumption this year and beyond as the newer, more efficient lighting continues to operate. As such, these programs have useful lives that extend beyond the first measure year of the program.

Adjustments are made to forecasts to include future changes such as:

- Decreases in consumption due to increased numbers of rooftop solar panel installations over time; and
- Increases in consumption due to increased numbers of electric vehicles over time

The sales forecast also includes a wholesale energy forecast for Sam Rayburn Municipal Power Agency. That forecast is based on historical load shape and energy consumption.

Load Forecasting

The long-term hourly load forecast is the result of the calibration of a monthly peak forecast, the monthly sales forecast, and estimated load shapes for each customer class.

Similar to the process used for the sales forecast, twenty years of “normal weather” data is used to convert historical load shapes into “normal load shapes”. This adjusts the historical consumption profiles by month and hour for year-over-year changes in days of the week, holiday schedules, and temperatures. For example, if the actual sales for ELL’s residential customers occurred during very hot weather conditions, the normal load shape would flatten the historic load shape. If the actual weather were mild, the normal load shape would raise the historic load shape. Each customer class reacts differently to weather, so each has its own weather response function.

The peak forecast is developed using historical calendarized sales, historical peaks, and degree days to develop relationships between peaks and energy. Those relationships are applied to the forecasted energy and use normal weather for the future forecast period.

As mentioned previously, the forecasted energy, the forecasted peaks, and the forecasted hourly profiles are calibrated together to ensure that all of the forecasted energy is accounted for while maintaining, as closely as possible, the forecasted peaks and shapes.

The final load forecasts include transmission and distribution losses, which are computed by class and separately for EGSL and ELL. Because line losses are applied to the respective classes, changes in customer class mix are taken into account for losses.

Resource Portfolio Needs

Long-term Capacity Considerations

Consistent with planning guidelines, ELL plans to meet capacity needs based on projected peak load requirements plus a 12 percent planning resource margin using installed capacity (for conventional generation and effective for renewable) to meet this need. The requirements shown below reflect this assumption and are adjusted to account for ELL’s current resource portfolio reflected in Table 2 and

Table 3 above. The requirements evolve over time as forecasted energy use changes and resources are assumed to deactivate. The Low, Reference, and High load scenarios attempt to bookend the effect changes to customer use patterns could have on ELL’s energy and peak requirements, absent the potential incremental industrial block load additions described later in this report.




Figure 8: ELL's Projected Long-Term Resource Requirements

Given planned additions, across each load scenario ELL expects that around 6 GW of replacement capacity is necessary to account for deactivating generation, expiring PPAs, and load growth.

ELL's Expected Energy Coverage

The company regularly assesses ELL's expected energy coverage utilizing production cost modelling to better understand the needs of ELL's customers. Illustrated below is ELL's annual projected energy generation based on its allocated share of resources based on the expected commitment and dispatch of those resources in MISO's energy market totaled. This is compared to the total amount of ELL's forecasted annual energy requirements. Any gap between generation and load on an annual basis indicates net purchases from the MISO market, and as such, is an indication of magnitude of customer energy exposure.




Figure 9: ELL's Expected Energy Coverage

Absent additional energy producing capacity past the SCPS and LCPS CCGT additions, ELL is expected to remain a net purchaser in MISO's energy markets. This energy position leaves ELL's customers subject to MISO's day ahead and real time energy markets for economic energy. Consistent with ELL's guiding principles of **Base Load Production Costs** and **Price Stability**, ELL seeks to meet its capacity needs through a balanced portfolio with resources that contribute to meeting its energy needs.

ELL's Planning Region Needs

Amite South is a constrained planning area in ELL's service area which contains a significant amount of high load factor industrial load. The area regularly relies on local generation as well as imports to serve peak load and transmission requirements. Further, a large fraction of ELL's legacy assets are located in the area as illustrated below.




Figure 10: ELL's Generation Fleet- Amite South View

These legacy units which are critical to local reliability, such as the Ninemile and Little Gypsy units, are currently greater than 45 years of age and are expected to deactivate over the planning horizon. The incremental resources of St. Charles Power Station and Washington Parish Energy Center are expected to support the local needs of the area; however, additional generation will be required in the region to replace these assets and support local requirements when legacy generation deactivates.

Legacy Gas Useful Life Assumptions

ELL plans its long term generation portfolio utilizing assumptions which have been developed through expert judgement, industry experience, and research into industry trends. One such assumption is the operating life for assets within the portfolio. Deactivation assumptions must be made to reasonably plan a portfolio of resources, but as more insight is gained over time, technology progresses, and industry conditions change, a reassessment may be required.


As the assumed deactivation dates near, or as equipment failures occur, cross-functional teams are assembled to evaluate whether or not to keep a particular unit in service for a specified amount of time and level of reliability.

Looking to the longevity of units similar to ELL's legacy gas units, an Electric Power Research Institute (EPRI) analysis performed in 2012 projected that the average age of natural gas steam turbine retirements as of 2016 would be 52.9 years old. A 2017 study performed by the Lawrence Berkley National Laboratory (and supported by the Department of Energy) produced similar results finding that the most common age of recently retired natural gas steam turbines was between 40 and 50 years. This is consistent with the 52.4 years average life of the Entergy Operating Companies' natural gas steam turbines either deactivated or retired since 2000. Given these trends, there is risk that ELL's legacy gas units may not be economic or feasible to operate through their assumed 60 year useful life.

Consistent with the Commission's Directive at the February 21, 2018 Business and Executive Session, ELL will complete a study of the economic viability of its legacy gas generators. This study will be finalized no later than six months following the commercial operation date of Lake Charles Power Station and will evaluate whether or not any of ELL's legacy gas units should be deactivated.

Potential for Block Load Additions

Sales and load forecasts for prospective large industrial growth are based on information gathered from prospective or existing (in the case of expansion) customers and are risk-adjusted based on the project status and account manager expertise. Moreover, some potential load growth is not captured within the load forecast due to an assumed low probability of that load materializing. However, large block additions can materialize quickly and ELL needs to be agile to respond to the need to serve that load. Not incorporated within the load forecast (due to lower probability of occurrence and/or updated information) is



As discussed previously, these industrial loads, at some level, are expected to require spinning mass generation to provide inertia to support the stability of the transmission system. Transmission needs related to industrial loads will continue to be evaluated and taken into account in the resource planning process going forward.

Combustion Turbine Based Technology

Similar to legacy gas, ELL must make assumptions regarding the longevity of generating assets to conduct portfolio analytics. For CT and CCGT technology, consistent with the Electric Power Research Institute and unless better information is available, ELL assumes a 30-year useful life. However, considering that deployment of F-frame style combustion turbines based resources began in the early 2000's, there is limited information available as to the disposition of the units after 30 years of continued operation. There is a potential that these units will continue to be economic to operate well into the 2030's, providing capacity and energy benefits to ELL's customers past their assumed useful lives. Shown in the figure below is the impact to ELL's long term capacity requirement should those resources extend beyond their assumed useful life and throughout the planning horizon.

As with all assets ELL maintains, as the unit life assumptions near the present, or as equipment failures occur, or as operating performance diminishes, ELL evaluates whether or not to keep a particular unit in service for a specified amount of time and level of reliability.

Environmental Considerations of the Existing Fleet

In light of industry trends concerning the economics of such units, ELL continuously monitors the economics of coal fired generation relative to deactivation and repowering alternatives. At this time, the key drivers indicate continued operation of such units provides benefits to ELL's customers. ELL will continue to monitor such facilities to understand the value they bring to customers, especially as underlying assumptions change regarding fuel prices, the potential creation of a price on carbon emissions and other environmental regulations, related policies affecting the economies of coal-fired generation, and customer preferences.

Summary of Types of Resources Needed

In order to continue to support customer's needs at the lowest reasonable cost, ELL plans to a portfolio of generation resources that includes sufficient capacity to meet ELL's peak load and reserve margin target of 12 percent and to satisfy MISO's Resource Adequacy Requirements while providing the efficient operating flexibility required to serve evolving customer demands.

As discussed below, to address ELL's additional energy needs there are a number of supply-side and demand-side alternatives available for meeting long-term resource needs. This includes incremental long-term resource additions from self-supply alternatives, acquisitions, and long-term PPAs. Demand-side alternatives including Energy Efficiency, Demand Response, and developing products and services can also provide solutions to meet long-term needs.

The portfolio design analytics outlined in more detail later within the document explore the value of renewables, dispatchable supply-side alternatives, and demand-side measures. The long-term planning horizon will likely include additions of renewable technologies such as solar. As the solar industry matures and the capital costs associated with these resources continue to

decline, solar is anticipated to become increasingly feasible as a utility-scale supply solution. As intermittent additions increase and ELL's legacy fleet deactivates, ELL will not only continue to see value in conventional generation (e.g. CCGTs) due to needed inertia for transmission reliability, but could also see increased value in additional flexible peaking and quick-start capability more indicative of internal combustion turbine, Frame CT, and Aeroderivative CT technologies.

ELL will continue to assess the likely increasing capacity, energy, and operational flexibility required over the long-term planning horizon. This ongoing assessment of the generation supply plan against dynamic factors like capacity requirements, operating roles, and evolving technologies allows ELL to continually improve efficiencies and reliability to develop the best possible solutions to address its customers' needs with the least cost solutions.



Section III

Assumptions

Supply Alternatives to Meet ELL Resource Needs

Technology Assessment

The IRP process considers a range of alternatives available to meet the planning objectives, including the existing fleet of generating units, as well as new demand-side management and supply-side resource alternatives. As part of this process, a Technology Assessment was prepared to identify a wide range of potential supply-side resource alternatives that merit more detailed analysis due to their potential to meet ELL's planning objectives of balancing reliability, cost, and risk. Alternatives evaluated are technologically mature and could reasonably be expected to be operational in or around the ELL service territory. A visualization and list of the technologies selected for further more detailed evaluation in the IRP included:




Figure 13: Technology screening curve illustration

- I. Natural Gas Fired Technologies
 - a. Combustion Turbine (CT)
 - b. Combined Cycle Gas Turbine (CCGT)
 - c. Aeroderivative CT

- d. Internal combustion engine (“ICE”) or reciprocating internal combustion engine (“RICE”)

II. Renewable Technologies

- a. Solar Photovoltaic (“PV”) (Tracking)
b. Wind (Onshore)

III. Energy Storage

- a. Battery storage technologies

Each of these technologies has advantages and disadvantages to consider when designing a resource portfolio to meet customers’ capacity needs. The information below summarizes some of those various considerations and provides major inputs, which were utilized in the portfolio analyses discussed later in the document.

Table 6: Gas-Fired Technology Considerations

	CT	CCGT	Aeroderivative CT	RICE
Description	Frame CTs are a mature technology. Low gas prices and continual heat rate and capacity improvements have made CTs the industry’s technology of choice for peaking applications. CTs can also help integrate renewables by providing quickstart (~10 minutes) backup power.	Modern combined cycle facilities provide efficiencies, moderate flexibility, and improved CO ₂ emissions relative to coal plants, making them suitable for a variety of supply roles (baseload, load-following, limited peaking). CCGT efficiency and flexibility is expected to continue to improve.	Aeroderivative CTs trade increased cost for greater flexibility (start time, ramp times), lower heat rates, and higher reliability relative to frame CTs.	RICEs are useful for applications requiring heavy cycling and ramping, as they incur lower O&M penalties when operated in this manner relative to other conventional peaker technologies. As renewable penetration increases, this technology will likely see increased deployment in North American power markets due to its flexibility and efficiency.
Advantages	<ul style="list-style-type: none"> • Low capital and staffing costs • Existing operating expertise • Flexible, quick start capability 	<ul style="list-style-type: none"> • Lowest heat rates • Moderate capital cost • Synergies with existing and planned fleet (e.g., parts, staff) 	<ul style="list-style-type: none"> • Higher flexibility • Moderate heat rates • High reliability 	<ul style="list-style-type: none"> • Low heat rates • Highest flexibility • No gas compression needed • Modular additions
Disadvantages	<ul style="list-style-type: none"> • Higher heat rates • Difficult to neatly match need (blocky additions) • High gas pressure requirements 	<ul style="list-style-type: none"> • Increases reliance on natural gas • Blocky additions • High gas pressure requirements 	<ul style="list-style-type: none"> • Moderate capital cost • High gas pressure requirements • Less experience with technology 	<ul style="list-style-type: none"> • Moderate capital cost • High variable operating cost • Less experience with technology


In addition to the qualitative factors considered above, the table below summarizes the cost information from the Technology Assessment for gas-fired generation.

Table 7: Gas-Fired Resource Assumptions

Technology		Summer Capacity [MW]	Capital Cost [2017\$/kW]	Fixed O&M [2017\$/kW-yr]	Variable O&M [2017\$/MWh]	Heat Rate [Btu/kWh]	Expected Capacity Factor [%]
CT / CCGT	1x1 501JAC	510	\$1,238	\$17.02	\$3.14	6,400	85%
	2x1 501JAC	1020	\$1,090	\$11.12	\$3.15	6,400	85%
	501JAC	300	\$833	\$2.84	\$13.35	9,400	10%
Aeroderivative CT	LMS100PA	102	\$1,543	\$5.86	\$2.90	9,397	20%
RICE	7x Wartsila 18V50SG	128	\$1,642	\$31.94	\$7.30	8,401	30%


Renewables (Solar PV and Wind)

In the last decade, the renewable energy industry has experienced substantial growth, driven in large part by cost declines, technological improvements, and environmental concerns. As shown in Figure 14, renewables' capital cost declines are particularly evident in utility-scale solar installations within the U.S. over the past five years. Among all technologically-feasible renewable energy options, solar and onshore wind resources are the most cost effective, commercially-available alternatives to meet ELL's capacity and energy needs.

Figure 14: Historical Utility-Scale Solar Capital Costs⁷

⁷Data adapted from NREL U.S. Solar Photovoltaic System Cost Benchmark, Q1 2017.

The costs of renewable generation have declined significantly in the previous five years, and this trend is expected to continue. As visualized below, installed costs of utility-scale renewables (wind and solar) in real dollars are expected to decline throughout the planning horizon.



The table below expands upon the opportunities presented by solar and wind generation. In general, advantages of renewables include zero emissions and fuel costs, which decrease reliance on fuel commodities. Disadvantages are related to relative land use compared with traditional alternatives as well as relative capacity contribution due to the intermittent nature of these energy sources.

Table 8: Renewable Technology Considerations

	Solar	Wind
Description	Solar capital costs have fallen dramatically in the last decade and continue to decline as the industry matures. Solar production roughly aligns with customer load patterns, but grid flexibility and quickstart backup generation are necessary to ensure reliability in the absence of large-scale, economic energy storage alternatives. The industry will continue to mature and solar energy is expected to continue to compete with gas-fired generation within the planning horizon, constrained mainly by site-specific performance and market conditions (e.g., construction cost, energy value).	The wind industry is mature relative to the solar industry. Current research focuses more on improving performance, rather than cost, through larger, taller turbines and improved control technologies (e.g., turbine alignment sensors, integrated battery storage). Wind is not likely to see extensive local deployment within the MISO South region but could play a role in the region’s energy mix if storage economics improve or significant high voltage direct current (HVDC) projects are completed.

[Redacted text]

Advantages	<ul style="list-style-type: none"> • Zero Emissions • No fuel cost • Capital costs continue to decline • Federal investment tax credits (ITCs) • Predictable energy curve 	<ul style="list-style-type: none"> • Zero Emissions • No fuel cost • Federal production tax credits • Efficiency continues to increase
Disadvantages	<ul style="list-style-type: none"> • Relative capacity value to traditional generation • Land-intensive • Integration requirements (responsive, quickstart generation is necessary to integrate large amounts of solar PV) • Site-specific performance 	<ul style="list-style-type: none"> • Relative capacity value to traditional generation • Land-intensive • Integration requirements (responsive, quickstart generation is necessary to integrate large amounts of wind) • MISO South not ideal for wind without incurring transmission or congestion costs

Additional unique qualities associated with renewable generation are summarized below.

Table 9: Additional Benefits of Renewables

Additional Benefits of Renewables	
Diversity	Renewables add fuel diversity and provide a hedge within gas-centric resource portfolios as ELL's ability to rely on coal for fuel diversity becomes uncertain
Infrastructure	Reduced infrastructure requirements (e.g., gas pipelines, water supply) increase siting flexibility
Scalability	Deployment can be scaled up or down to meet capacity needs more easily relative to conventional alternatives
Carbon and other emissions	Renewables offer customers protection against uncertainty related to potential CO ₂ costs and the increasing stringency of other emissions regulations
Customer Engagement	Gaining experience with renewables can help ELL take advantage of opportunities such as community solar, deployment of distributed energy resources ("DERs"), and the integration of advanced metering infrastructure ("AMI")

The table below provides a summary of operational costs and performance assumptions for solar and wind technology used within the 2019 IRP.

Table 10: Renewable Modeling Assumptions

	Solar	Wind
Fixed O&M (2017\$/kW-yr)	\$15.78	\$23.46
Useful Life (yr)	30	25
Capacity Factor	26%	34%
Capacity Value	50%	15.6%
Tracking Type	Single Axis	N/A

Energy Storage Systems

Energy storage, particularly in the case of battery-enabled storage, provides a range of attributes that differ from traditional supply-side options discussed previously, such as:

- The ability to store energy for later commitment and dispatch,
- Ability to discharge in milliseconds and fast ramping capability,
- Rapid construction (on the order of months),
- Modular deployment,
- Portability and capability to be redeployed in different areas,
- Small footprint (typically less than an acre), allowing for flexible siting, and
- Low round-trip losses compared to other storage technologies (such as compressed air).

Battery storage system benefits lie in the attributes highlighted above and the ability to offer stacked values through multiple revenue streams to benefit customers. Battery storage effectively enables an intra-day temporal shift between energy production and energy use. Energy can be absorbed and stored during off-peak/low cost hours and discharged during on-peak/high cost hours. The spread (i.e., cost difference) between the time periods creates cost savings for customers and may produce a reduction in emissions. In addition to energy market attributes, battery storage systems qualify in some markets for various ancillary service applications such as regulation, reserves, and voltage regulation, and qualify for MISO's capacity market, given sufficient discharge duration. Lastly, energy storage may, depending on location and characteristics, offer the capability of transmission and distribution cost deferral.

Given the current higher installed cost, energy storage faces challenges for high-deployment potential. The typical on-peak/off-peak spread remains low in MISO South, which may limit arbitrage potential. Additionally, MISO's ancillary services market is limited today and fully met with existing resources but continues to evolve. ELL will continue to monitor MISO's energy and ancillary market conditions to identify energy storage potential. At the time of this report, the fixed costs of energy storage today remain above a new build CT, as visualized below.




Figure 16: Storage and CT Cost Comparison⁹

For storage, the key to achieving positive net benefits today is identifying the right transmission use-case. For example, battery storage can provide transmission benefits by avoiding investments required due to line overloads. In addition to these peak-shaving applications, energy storage sited in location-specific areas provide voltage support, which mitigates the effects of electrical anomalies and disturbances. However, if sited and/or operated sub-optimally, storage can increase transmission congestion and could drive otherwise unnecessary transmission improvements. Also, charge and discharge cycles must be optimized so as not to conflict with transmission reliability and/or economics.

Similar to what has been seen in recent years within the solar industry, it is expected that battery storage costs will decline within the planning horizon. Therefore, while limited deployment may make sense today for ELL customers, this technology will continue to evolve, and additional applications could present themselves in the future.

Demand-Side Alternatives

For the 2019 IRP, ELL engaged the services of ICF International to assess the market-achievable potential for DSM programs that could be deployed over the planning horizon. These programs are then made available to the AURORA capacity expansion model, to select the least cost portfolio given a set of assumptions contained within a future time period. Information regarding the DSM programs explored, both Energy Efficiency and Demand Response programs, is summarized below.

Energy Efficiency

The International Energy Agency defines Energy Efficiency **as achieving the same services with less energy**. This ensures an opportunity for ELL to serve its customers by providing energy savings. The method utilized by ICF for determining EE is summarized below.

⁹ The capital cost assumptions for storage is based on a confidential IHS Markit forecast.




Figure 17: Energy Efficiency study approach

ICF’s energy efficiency modeling included 2 potential scenarios:

- **Current Programs** based on ELL’s Quick Start PY2 designs, but with expanded budgets, and
- **Expanded Programs** which included current programs and new best practice programs.

The total potential of each EE scenario is outlined in Figure 18.




Figure 18: Current and Expanded EE Program Potential

Demand Response

Demand response provides an opportunity for consumers to play a significant role in the operation of the electric grid by reducing or shifting their electricity usage during peak periods. DR offerings which ICF found to be cost effective using the Total Resource Cost test are shown below.

Table 11: Cost Effective DR

Class	Measure
Residential	Room AC Switch
	Central AC Switch
	Smart Thermostat
	Water Heater Switch
Commercial	Central AC Switch
	Water Heater Switch
	Smart Thermostat

These programs were made available to the AURORA model for a reference and high case, differing in terms of pricing signals and adoption rates. The total annual MW savings made available for selection is illustrated below, representing approximately 400 MW in the reference case and 500 MW in the high case. The cost effective DR solutions included in the model do not include rate offerings recommended by ICF, such as dynamic pricing alternatives. With the deployment of AMI, ELL is well positioned to begin making offerings for dynamic pricing alternatives that will send appropriate price signals to customers for DR purposes and may be more preferable to ELL customers than traditional time of use rate structures.




Figure 19: Achievable DR

DSM program costs utilized in the IRP include incentives paid to participants and program delivery costs such as marketing, training, and program administration. Program delivery costs were estimated to reflect average annual costs over the 20-year planning horizon of the DSM Potential Study. The costs reflect an assumption that over the planning horizon, program efficiencies will be achieved resulting in lower expected costs. That is, as experience is gained with current and future programs, actual costs may decrease over time. As such, actual near-term costs associated with current and future programs may be higher than the assumptions used to determine the optimal cost-effective level. Therefore, future DSM program goals and implementation plans should reflect this uncertainty.

Summary of Emerging Supply Trends and Implications

Expanding and changing supply alternatives and technologies have provided increased opportunities and alternatives to address planning objectives. Advancing technologies (including, but not limited to, advances in generating technology) provide new opportunities to meet customer needs reliably and affordably. ELL's planning processes strive to understand these technological changes in order to enable it to design a portfolio of resources and services that meet customers' needs and wants.

Renewable energy resources, especially solar, have emerged as viable economic alternatives and are expected to continue to improve throughout the planning horizon. However, increased deployment of intermittent generation has increased the value and necessity of flexible, diverse supply alternatives. Smaller, more modular resources, such as peaking generation and battery storage, provide an opportunity to reduce risk and better address locational, site-specific reliability requirements while continuing to support overall grid reliability. Combining these trends provides additional opportunities to meet ELL's planning objectives.

Additionally, Integrated Grids have become increasingly viable and important, thanks to the increased options of grid-connected devices for energy storage. The development of a more complex energy system can help manage ELL customer's electrical requirements.

Natural Gas Price Forecast

The near-term portion (the first year) of the natural gas price forecast is based on NYMEX Henry Hub forward prices, which are market future prices as of January 2018. Because the NYMEX futures market becomes increasingly illiquid as the time horizon increases, NYMEX forward prices are not a reliable predictor of future prices in the long term. Due to this limitation, the long-term point of view regarding future natural gas prices utilizes a consensus average of several expert independent, third-party consultant forecasts. The long-term natural gas price forecast used in the IRP also includes cases for high and low gas prices to support analysis across a range of future scenarios. In levelized 2019 dollars per MMBtu through the IRP period (2019-2038), the reference case natural gas price forecast is \$4.51, the low case is \$3.07, and the high case is \$6.28.

Each gas price sensitivity is illustrated below and is described in more detail later in this section. Each of the IRP Futures assumes the natural gas price forecast sensitivity appropriate for the future world envisioned.




Figure 20: Natural Gas Price Forecast

CO₂ Price Assumptions

ELL's point of view is that national carbon regulation or pricing for the power generation sector will occur; however, the timing, design, and outcome of any carbon-control program remain uncertain.

The scenarios forecasted and utilized in ELL's evaluations are based on the following three cases:

1. **Low Scenario** - A \$0/ton CO₂ price, representing either no program or a program that requires "inside-the-fence" measures at generating facilities, such as efficiency improvements, that do not result in a tradable CO₂ prices. This scenario is basically consistent with the Affordable Clean Energy ("ACE") rule proposed by the EPA in August 2018.
2. **Reference Scenario** - A "CPP Delay" case reflects a 6-year delay in the implementation of the Clean Power Plan or similar national regulation and represents a regional mass-based cap consistent with achieving the final CPP requirements but delayed by approximately 4-6 years due to the federal administration change in 2017 and consistent with the President's executive order in March 2017; and
3. **High Scenario** - A "National Cap and Trade" High Case assumes a national cap and trade program that begins in 2028 and targets an approximately 80 percent reduction from 2005 sector Emissions by 2050. This case is generally consistent with the 2030 and 2050 emission reduction targets developed by the Intergovernmental Panel on Climate Change and anticipated by the Paris Agreement.




Figure 21: CO₂ Price Forecast



Section IV

Portfolio Design Analytics

Futures

The IRP analysis was performed using a scenario approach, relying on futures to assess supply portfolios across a range of economic outcomes. The various portfolios developed, some of which were based on the market value assumed under each future, were tested across each future to generate a total supply cost unique to each portfolio/future combination. Details regarding the evaluated portfolios and total supply cost results are described further below.

For the 2019 IRP, ELL utilized a set of four futures which vary based on economic, policy, and customer behavior assumptions that impact market prices, including:

- Peak load and energy growth
- Natural gas prices
- Coal and legacy gas generation deactivations
- Renewable penetration
- CO₂ prices

The four futures utilized by ELL for the 2019 IRP are given below along with major assumptions unique to each future.

Table 12: Overview of Futures

	Future 1	Future 2	Future 3	Future 4
	Progression Towards Resource Mix	Policy Reversion (Gas Centric)	Decentralized Focus (DSM & Renewables)	Economic Growth w/ Emphasis on Renewables
Peak Load & Energy Growth	Reference	High	Low	High
20-Year Levelized Natural Gas Prices (2019\$)	Reference (\$4.81)	Low (\$3.27)	Low (\$3.27)	High (\$6.70)
Market Coal & Legacy Gas Deactivations	Reference (60 years)	55 years	50 years	55 years
Magnitude of Market Coal & Legacy Gas Deactivations	12% by 2028 54% by 2038	31% by 2028 88% by 2038	54% by 2028 91% by 2038	31% by 2028 88% by 2038
Incremental Market Renewables / Gas Mix				
CO₂ Price Forecast	Reference	None	High	Reference

Each future represents a unique set of key market drivers. A summary of each future is provided below.

Future 1: Progression Towards Resource Mix

The market experiences flat to declining electric usage per customer (UPC) in residential and commercial sectors due to increases in energy efficiency. This is partially offset by industrial growth and growth in residential and commercial customer counts. Coal economics continue to face pressure from low natural gas prices. Renewables and gas play balanced roles in replacing retiring capacity to promote fuel diversity in long-term resource planning.

Future 2: Policy Reversion

Residential and commercial customer growth rates increase due to economic development and decreased energy efficiency gains due to a shift in public policy (e.g., discontinuation of Energy Star program). This increase, combined with increased industrial sales growth due to realization of lower-probability projects, results in high peak and energy load growth. Sustained low gas prices accelerate legacy gas and coal retirements due to economic pressure. Sustained low gas pricing, a low (zero) CO₂ price, and a shift in public policy lead to gas-fired generation comprising the majority of capacity additions, complemented by some renewables.

Future 3: Decentralized Focus

Residential, commercial, and industrial growth rates decrease due to strong customer preferences for energy efficiency and distributed energy resource, resulting in a low (compared to Future 1) energy and peak load growth. Aggressive CO₂ cost and gas prices drive coal and legacy gas plants to retire much earlier than anticipated. The capacity and energy is replaced by an aggressive penetration of renewables complemented by gas-fired generation.

Future 4: Economic Growth with Emphasis on Renewables

Residential and commercial customer growth rates increase due to economic development and decreased energy efficiency gains due to a shift in public policy (e.g., discontinuation of Energy Star program). Load growth is further driven by industrial sales growth due to realization of lower-probability projects. Political and economic pressure on coal and legacy gas plants accelerates retirements. Moderate CO₂ pricing, along with political and economic factors, drive an aggressive portfolio of renewables and gas-fired technology to replace retiring capacity.

Market Modeling

The first step within the market modeling process is to utilize the AURORA¹⁰ production cost model to develop a projection of the future market supply based on the specific characteristics of each future. The energy market simulation results in hourly energy prices for each of the four futures. This projection encompasses the power market for the entire MISO footprint (excluding ELL). The purpose of this step is to provide projected market power prices to assess potential portfolio strategies for ELL within each future. In order to achieve this, assumptions are required about the future supply of power, as outlined in the previous “Futures” section. Represented below are the projected average annual MISO (excluding ELL) power prices under each future.

¹⁰ The AURORA model is the primary production cost tool used to perform MISO market modeling and long-term variable supply cost planning for ELL. AURORA supports a variety of resource planning activities and is well suited for scenario modeling and risk assessment modeling through hourly simulation of the MISO market. It is widely used by a range of organizations, including large investor-owned utilities, small publically-owned utilities, regulators, planning authorities, independent power producers and developers, research institutions, and electric industry consultants.




Figure 22: Average Annual MISO South Non-ELL LMP

Portfolio Design

Following the market modeling process, which results in Locational Margin Prices (“LMPs”) for the non-ELL region, the AURORA Capacity Expansion Model was used to identify economic type, amount, and timing of supply-side resources needed to meet reserve margin requirements. The result of this process is a portfolio of supply-side alternatives that produces the lowest total supply cost to meet the identified need within the constraints defined in each of the four futures (the “optimized portfolio”).

Solar Capacity Credit Modeling

For the 2019 IRP, ELL sought to take into account integration considerations of intermittent generation. In order to reasonably bound the amount of solar generation the capacity expansion model would include, it was assumed for modeling purposes that the capacity contribution of solar diminished as a function of the amount of incremental solar added in the ELL footprint. The concept that solar provides diminishing returns in capacity and energy value is a relatively recent notion that has been further explored in works by CAISO¹¹ and MISO¹² to great detail and generally is due to solar production shifting a load serving entity’s net peak such that every incremental unit of solar provides less value in supporting reliability needs. For the purposes of capacity expansion within the IRP, ELL used the following accreditation of solar for AURORA when making portfolio selections.

¹¹ <https://www.nrel.gov/docs/fy16osti/65023.pdf>

¹² <https://cdn.misoenergy.org/20180605%20RIIA%20Workshop%20Presentation213125.pdf>




Figure 23: Solar Credit Step-Down as Penetration¹³ Increases

This is a heuristic approach which, rather than rely on any specific analysis, utilizes a step-down approach from 50% credit (the current 1st year capacity credit a solar resource is granted in MISO) to attempt to capture the diminishing returns solar has within a portfolio. This assumption is limited to only the AURORA capacity expansion. For the purpose of computing a total supply cost to customers, ELL defaulted to the 50% credit consistent with current MISO practice.

Portfolio Results

The figures below demonstrate the timing of resource additions and existing capacity throughout the ELL IRP evaluation period of 2019-2038. For each optimized portfolio, the load requirement is reflective of the future for which the portfolio is optimized (e.g., Portfolio 1 is optimized in Future 1) and includes the assumed effects of incremental DSM on the peak load requirement.

Future 1

Future 1 is defined by reference load growth and gas prices and a one-third to two-thirds split of renewables to gas for incremental market additions. Under reference assumptions, Future 1 produces a diverse portfolio of resources which includes baseload energy producing resources, grid balancing gas, renewables, energy storage, and DSM. Based on nameplate capacity, renewable additions make up nearly half of the installed capacity in ELL's portfolio or 4.4 GWs, indicating the value intermittent generating resources could provide Louisiana customers. 4.1 GW of low heat rate combined cycle is added to address ELL's expected energy needs, in addition to accounting for future deactivation of energy producing

¹³ Here solar penetration is defined as nameplate capacity of installed solar as a percentage of peak demand.

Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan

resources. 1.2 GW of CT was selected to provide capacity and energy in high load / market price events. The additions are shown in the following visual.




Figure 24: Capacity Expansion Portfolio Future 1¹⁴

¹⁴ Reference Supply Deficit includes the impact of existing and firm planned resources.

Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan

Future 2 is defined by high load growth, low gas prices, and a one-fourth to three-fourths split of renewables to gas for incremental market additions. Zero CO₂ price and accelerated legacy gas and coal retirements, along with the replacement of these retirements with efficient generation, lead to sustained low LMPs over the planning horizon. Despite low gas and CO₂ prices, a similar magnitude of dispatchable gas resources is selected. Low LMPs may be providing downward pressure on the value of renewables. Ultimately 1 GW of solar is selected in this future. Energy storage and DSM appears to continue to add value in both in Future 1 and Future 2.




Figure 25: Capacity Expansion Portfolio Future 2

Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan

Future 3 is defined by low load growth, low gas prices, and more accelerated (relative to Future 2) legacy gas and coal retirements. As shown in Figure 22 above, High CO₂ price and 50/50 renewables to gas incremental market additions lead to volatile LMPs over the planning horizon. Similar to Futures 1 and 2, ~4 GW of CCGT capacity adds value to ELL’s portfolio. High CO₂ and low load growth dampen grid-balancing gas additions. High CO₂ may also be driving the significant deployment of renewables (~50% of installed supply-side MW).




Figure 26: Capacity Expansion Portfolio Future 3

Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan

Future 4 is defined by high load growth, high gas prices, and accelerated legacy gas and coal retirements. Reference CO₂ price and 50/50 renewables to gas incremental market additions lead to LMPs that are generally high but volatile. Energy needs driven by high load growth assumptions and high LMPs result in the addition of ~4 GW CCGT and grid balancing dispatchable capacity in the form of peaking gas generation and energy storage. The remainder of ELL’s capacity and energy needs are met through renewable deployments of 3.7 GW solar and 3.8 GW wind. High load, gas prices, and market prices, likely drive renewable deployment, yielding the most renewables added of the four futures developed.




Figure 27: Capacity Expansion Portfolio Future 4

A **summary of developed futures** is given below. Each future resulted in a diverse portfolio, indicating the value multiple technologies and fuel types bring to ELL customers. Capacity Expansion results generally indicated **CCGTs**, **renewables**, and **DSM** are economic under the futures tested in the 2019 IRP, and are able to provide value under a wide array of potential market and policy outcomes.

Table 13: Overview of Capacity Expansion Outcome (Numerical Values in Table are MW's)

Resource Type	Builds			
	P1	P2	P3	P4
CCGTs	4080	4080	4590	4590
J - CTs	1200	1500	0	600
Solar	3200	1000	1700	3700
Wind	1200	0	2000	3800
Batteries	100	600	0	400
DSM	554	580	554	53
Total	10,143	7,546	8,653	13,148
Effective	6,685	6,926	5,800	7,076

Non-Baseload Additions

Peaking

Solar

Wind

Battery+DSM



Referring to Figure 24 through Figure 27, **solar appears to be the preferred renewable alternative over wind initially**, as the model selects solar resources prior to wind in all futures. The capacity expansion algorithm selects at least 1 GW of solar before transitioning to **adding solar and wind in concert**. This could be due to the diminishing returns of solar capacity value, after which wind adds value to a portfolio containing solar by providing off-peak energy. This indicates that ELL should continue to monitor solar buildout within the portfolio, continue to assess the cost and performance of wind, and understand the value a combination of renewables alternatives may bring customers in the future.

Discussion of Results

The Total Relevant Supply Cost ("TRSC") for each portfolio was calculated in each of the four futures described earlier. The total relevant supply cost was calculated using:

- **Variable Supply Cost** - The variable output from the AURORA model for each portfolio in each of the futures, which includes fuel costs, variable O&M, CO₂ emission costs, startup costs, energy revenue, and uplift revenue
- **Levelized Real Non-Fuel Fixed Costs** - Return of and on capital investment, fixed O&M, and property tax for the incremental resource additions in each portfolio
- **Demand Side Management (DSM) Costs** – Implementation costs for incremental DSM programs selected in each portfolio
- **Capacity Purchases/(Sales)** - The capacity surplus (or deficit) in each portfolio multiplied by the assumed capacity

price

Shown below is the present value of the total relevant supply cost for each portfolio by future. The total relevant supply cost of each portfolio is comparable across each future, thus allowing an ability to evaluate a portfolio's relative performance across futures.

Table 14: PV of Total Relevant Supply Costs by Future

PV of Total Relevant Supply Cost (MM, 2019\$, 2019-2038)				
	Future 1	Future 2	Future 3	Future 4
Portfolio 1	\$26,294	\$21,816	\$22,224	\$35,803
Portfolio 2	\$26,534	\$21,460	\$22,492	\$36,489
Portfolio 3	\$26,557	\$21,787	\$21,876	\$35,872
Portfolio 4	\$27,099	\$22,647	\$22,431	\$35,767

The columns in Table 15 below provide the rankings of each of the modeled portfolios within each of the futures based on the economic performance of the portfolios shown above.

Table 15: Economic Portfolio Ranking by Future

Portfolio Rankings				
	Future 1	Future 2	Future 3	Future 4
Portfolio 1	1	3	2	2
Portfolio 2	2	1	4	4
Portfolio 3	3	2	1	3
Portfolio 4	4	4	3	1

The relative difference between each portfolio and the least cost portfolio within each future is quantified below.

Table 16: PV of Total Relevant Supply Cost Variance to Least Cost Portfolio

PV of Total Relevant Supply Cost (MM, 2019\$, 2019-2038)				
	Future 1	Future 2	Future 3	Future 4
Portfolio 1	\$0	\$355	\$348	\$36
Portfolio 2	\$240	\$0	\$616	\$722
Portfolio 3	\$263	\$327	\$0	\$105
Portfolio 4	\$804	\$1,186	\$555	\$0

The performance of each portfolio within Future 1, measured by total relevant supply cost, is visualized below.




Figure 28: Total Relevant Supply Cost in Future 1

The Capacity Expansion portfolios should perform well from a total relevant supply cost perspective as the AURORA model was configured to produce optimal resource alternatives based on the inputs given. In addition to least cost planning, ELL must also balance the planning objectives of risk mitigation and reliability when determining ELL’s Preferred Portfolio. Table 15, above, demonstrates that the portfolios optimized through Capacity Expansion were the lowest cost portfolios in the futures for which they were optimized, which is expected.

Assessment of Risks

The purpose of the risk assessment is to give ELL an indication of the variability of a portfolio’s costs as underlying assumptions change (e.g. natural gas prices, CO₂ policy, load, market composition) using the metric of TRSC of each portfolio as it performs in the four futures developed for the 2019 IRP. This assessment, in part, quantifies the risk around price stability for each portfolio and how well each portfolio performs across a range of futures.

Cost as Measured by Expected Value

To perform an assessment of risks between portfolios generated for the 2019 IRP, ELL first computed the *expected value* (“EV”) of each portfolio across each of the four tested futures. Assuming that any of the given futures are equally likely to occur, the expected value for each portfolio was calculated as the simple average of total supply cost across futures. The results for each portfolio tested in each future are shown below.




Figure 29: Determination of Portfolio Expected Value

The expected value measures the cost that can be expected of each portfolio across a range of potential outcomes.

Risk as Measured by the Risk Premium

The **risk premium** monetized the risks unique to each portfolio and is determined by risk weighting ELL's customers' potential **Exposure** (Portfolio Max Cost Future – EV). The Exposure was probability weighted by 25%, stemming from ¼ chance of the high cost future occurring. To illustrate, an example is shown below.

Table 17: Determination of Portfolio Risk Premium

Portfolio 1	Description	Value (\$B)
Expected Value ("EV")	The average TRSC for a portfolio across the four futures	26.5
Exposure	Max cost future (future 4) - EV	9.3
Risk Premium	Probability weighted (25%) of Exposure	2.3

The incorporation of this metric allowed portfolios of differing risk characteristics to be compared. Ultimately, the risk premium described the impact that portfolio costs are greater than expected. Conversely, ELL also computed the **upside potential** of each portfolio. The upside potential measures the ability for total supply costs to be less than the expected value (i.e. a benefit to ELL's customers) and is calculated in a similar manner to the risk premium utilizing the least cost future for a given portfolio.

Cost/Risk Tradeoff and Conclusions

Using this framework, the costs and risk of each portfolio are visualized below.




Figure 30: Cost and Risk Profiles of Each Portfolio

From an expected value standpoint, Portfolios 1 and 3 are the lowest on an expected value basis, both yielding ~\$26.5B in customer costs. Portfolio 1 is the least expected cost and has the lowest Risk Premium, with Portfolio 3 approximately \$10M greater in cost and risk. Considering potential benefits, Portfolio 3 has the potential to provide the most upside to ELL's customers, with a \$20M Upside Potential over Portfolio 1. This analysis indicates Portfolios 1 and 3 are generally least cost across the futures tested, and have similar expected costs and risk profiles.

Table 18: Portfolios and Planning Guidelines

Planning Guideline	Cost	Risk	Reliability	Aligned with Planning Guidelines
2019 IRP Metric	Expected Value	Risk Premium	12% PRM	
Portfolio 1	✓	✓	✓	✓
Portfolio 2			✓	
Portfolio 3	✓	✓	✓	✓
Portfolio 4			✓	

Portfolio 1 and Portfolio 3 balance ELL's planning objectives of **Cost** and **Risk** while considering **Reliability**. Examining the composition of these portfolios, these portfolios incorporate a balance of **CCGT**, **Renewables**, and **DSM**. The reference CO₂ assumptions seen in Future 1 bring flexible, dispatchable gas alternatives (in this case CTs) into consideration, while no CO₂ is likely to result in similar conclusions.

Energy Storage was selected in small amounts in Portfolio 1 (100MW). Given policy changes, market conditions, cost declines, and performance improvements, storage may become increasingly cost effective for ELL's customers. Results suggest continuous monitoring of storage and consideration of potential pilot projects is warranted.

ELL continues to see CCGTs, similar in type to Ninemile 6, St. Charles Power Station, and Lake Charles Power Station, provide value to customers by being selected in all futures. This technology type is unique among generation alternatives in providing economic baseload power and support to the transmission system to enable the high load factor demand that ELL serves in the industrial corridors within WOTAB and Amite South. Though intermittent and not capable of providing the inertial support to the transmission system, inverter-based resources such as wind and solar provide an opportunity for ELL to diversify its portfolio with assets not dependent on fuel prices or CO₂ prices and align with customer preferences for sustainable generation. Finally, the IRP analytics continue to show the value of efficiency and demand response as a resource by both reducing demand and enabling customers an active role in the grid.

Though analytics have provided insight into the value of a changing resource mix, more detailed analyses will be required as ELL executes on any future supply alternatives. Such analyses will need to account for current market conditions, availability of supply alternatives, customer preferences, feasibility and practicality of certain supply options, ELL's energy needs, local reliability criteria, and transmission planning requirements.



Section V

The Path Forward (Action Plan)

ELL considers a number of factors when designing an IRP strategy that will enable it to continue serving its customers' power needs as reliably and affordably as possible. Below are the main considerations ELL believes will be important to keep in mind as it pursues a path forward to a strong energy future for ELL customers.

Legacy Generation Economic Study

Consistent with Louisiana Public Service Commission's directive at the February 21, 2018 Business & Executive Session, ELL will undertake and complete a study of the economic viability of its legacy gas generators. This study will be finalized no later than six months following the commercial operation date of Lake Charles Power Station. This study will evaluate whether or not any of ELL's gas units should be deactivated in light of the modernization of ELL's generating portfolio, including the Lake Charles and St. Charles Power Stations. This evaluation will also provide additional insight into the transmission and generation support needed within Amite South given the current generation fleet, existing load and potential load growth within the region. This detailed evaluation will more fully inform ELL's generation portfolio needs going forward.

Integration of More Modular Supply

Previous additions to ELL include large, gas fired central station facilities such as the Union, St. Charles, and Lake Charles Power Stations, and the Washington Parish Energy Center. Going forward, as customers are increasingly interested in sustainable energy generation, ELL is considering the value that more modular additions bring such as:

- Renewable energy resources (distributed and centralized),
- Emerging technologies such as storage,
- Other grid balancing supply which is expected to be more modular in nature (e.g. RICE).

In LPSC Order No. I-33014, which reviewed the Company's first IRP cycle, the Commission noted the Company's intent to conduct the 2016 Renewables RFP in order to determine the cost-effectiveness, viability, and performance of certain renewable technologies in Louisiana. As a result of that RFP, ELL has executed a PPA on a 50 MW solar photovoltaic resource – the largest of its kind for the Company and the state of Louisiana. ELL anticipates the Commission's potential certification of that PPA in early 2019. Expanding on and building out ELL's capabilities could prove critical as it continues to meet changing consumer demands while finding new, more sustainable ways to meet its region's energy needs. Agility from both the LPSC and ELL may be needed to quickly evaluate and procure emerging technologies that provide value to customers in terms of least cost, enhancing reliability, and diversifying ELL's portfolio.

Renewable Energy Pricing Tariff

In conjunction with its first utility-scale solar resource, ELL is seeking Commission authorization of an Experimental Renewable Option and Experimental Renewable Option Rate Schedule, which provides pricing that is tied directly to

renewable generation. Certain of ELL's commercial and industrial customers have expressed a desire for a rate option that would provide them access to renewable resources. In response, ELL has proposed the Experimental Renewable Option ("ERO") and Experimental Renewable Option Rate Schedule ("Schedule ERO") to meet those customers' goals. The proposed ERO provides eligible ELL customers, which are defined in Schedule ERO, with an opportunity to voluntarily match a portion of their annual energy use with renewable energy. In addition, enrolled customers will also receive the benefit of having the renewable energy credits associated with the elected amount of capacity from the renewable energy resource retired on their behalf.

Battery Storage

As outlined in greater detail in the IRP, battery storage has the potential to provide an array of benefits, including the ability to store energy for later use and delivery, rapid construction, a significantly smaller footprint that allows for more flexible siting and greater portability to enable redeployment in different areas.

Though battery storage costs are currently high relative to other alternatives, these costs are expected to decline within the planning horizon. Smaller scale deployments or pilots may provide the opportunity to gain operational experience while mitigating significant cost concerns. ELL will continue to monitor the cost and performance of storage technologies and seek opportunities for deployment within ELL's service territory. In addition to the cost and performance of storage, market constructs enabling storage are developing and require close attention to fully understand the value storage may provide to ELL's customers.

Demand Side Management (DSM) and Demand Response Tariffs

The IRP analytics indicated the value DSM may bring ELL's customers. ELL intends to conduct more detailed analysis of those Demand Response ("DR") and Energy Efficiency ("EE") programs that proved to be economic in its modeled portfolio results. In addition to the programs shown to be economic in the IRP analysis, and in response to customer feedback in this IRP cycle, ELL will develop and offer new interruptible tariffs with options for participation in the MISO energy and capacity markets.

ELL will design and offer these new demand response tariffs that will be generally available to customers who meet the criteria set out in the tariffs. Designing the pricing under such tariffs must carefully take into account the value of the demand response provided, so as not to unduly burden non-participating customers. Once offered, these demand response tariffs will provide ELL with real information about the viability of demand response within its footprint. With the deployment of its Advanced Metering System, ELL will be well positioned to begin making offerings for dynamic pricing alternatives that will send appropriate price signals to customers for DR purposes and may be more preferable to ELL customers than traditional time of use rate structures.

Growth and Reliability Study

ELL, like all LSEs within MISO, is responsible for planning and maintaining a resource portfolio to meet its customers' power needs. The Commission has acted as a steward of responsible system planning through various requirements, including the IRP requirement giving rise to this report, as well as other requirements such as periodic reporting on load forecasts and resource certifications. Distribution electric cooperatives, however, were exempted from the IRP order on the basis that they have a full requirement contract. It now appears, however, that some cooperatives are attempting to enter into new wholesale supply agreements in connection with block load additions without LPSC engagement in that resource planning procurement effort.

To the extent that distribution electric cooperatives or any other entities within the MISO market overly rely on the short-term MISO capacity market to serve load, such reliance could have unintended consequences on reliability and electricity prices in the state. As such, ELL plans to undertake a study to evaluate load growth and unit deactivations not accounted for

(Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan)

in the Commission's current long-term planning processes in order to measure potential impact on ELL customers and system reliability, which may affect ELL's resource needs.

Appendix A Actual Historic Load and Load Forecast

Historic Peak Demand and Energy

Table 1: Actual Historic Energy (GWh) (Includes T&D Losses)

	Residential	Commercial	Industrial	Governmental	Total
2008	14,054	11,303	22,672	707	48,737
2009	14,473	11,480	22,052	705	48,709
2010	15,836	12,018	24,454	724	53,032
2011	15,431	11,971	26,115	731	54,248
2012	14,583	11,977	26,590	743	53,894
2013	14,737	11,980	27,039	759	54,516
2014	15,147	12,141	28,396	769	56,453
2015	15,129	12,294	29,120	793	57,336
2016	14,511	12,060	29,964	834	57,369
2017	14,035	11,917	31,264	830	58,046

Table 2: Summer and Winter Historical Peaks (MW)¹⁵

	Summer	Winter
2008	9,347	7,970
2009	9,503	7,678
2010	9,400	8,544
2011	9,656	8,549
2012	9,607	7,602
2013	9,763	7,958
2014	9,493	9,073
2015	10,358	8,824
2016	9,857	7,978
2017	9,968	8,634

Table 3: Historic Monthly Energy (MWh)¹⁶

	Residential	Commercial	Industrial	Governmental	Total
1/1/2008	1,178,957	890,261	1,967,233	59,637	4,096,089
2/1/2008	1,131,146	867,275	1,875,010	61,299	3,934,730
3/1/2008	905,612	809,846	1,797,068	58,147	3,570,673
4/1/2008	883,998	830,460	1,929,429	57,222	3,701,108
5/1/2008	967,857	887,553	1,928,783	57,183	3,841,375

¹⁵ Actuals are not available for revenue classes.

¹⁶ Including T&D Losses to match forecasts values

6/1/2008	1,414,837	1,063,469	2,023,645	60,816	4,562,768
7/1/2008	1,579,841	1,121,010	1,960,113	62,143	4,723,107
8/1/2008	1,632,760	1,127,893	2,053,111	60,798	4,874,561
9/1/2008	1,372,973	1,037,163	1,976,185	59,011	4,445,331
10/1/2008	1,120,924	961,087	1,419,183	58,570	3,559,764
11/1/2008	883,573	876,939	1,965,539	55,726	3,781,777
12/1/2008	981,895	830,009	1,777,047	56,310	3,645,261
1/1/2009	1,139,477	893,683	1,663,868	57,436	3,754,465
2/1/2009	1,053,420	828,200	1,730,252	59,509	3,671,380
3/1/2009	946,319	838,872	1,547,639	56,516	3,389,346
4/1/2009	850,690	842,751	1,745,748	57,922	3,497,111
5/1/2009	1,023,946	892,404	1,876,409	57,455	3,850,214
6/1/2009	1,306,627	1,007,157	1,897,906	57,422	4,269,113
7/1/2009	1,753,969	1,140,663	1,830,230	59,369	4,784,231
8/1/2009	1,622,111	1,108,780	1,923,894	59,679	4,714,465
9/1/2009	1,506,026	1,123,984	2,025,297	59,364	4,714,671
10/1/2009	1,335,725	1,058,101	1,979,013	61,096	4,433,935
11/1/2009	943,871	899,659	1,952,951	59,646	3,856,127
12/1/2009	990,426	845,808	1,878,460	59,134	3,773,828
1/1/2010	1,484,586	958,904	1,853,380	67,914	4,364,784
2/1/2010	1,250,018	884,697	1,892,252	62,595	4,089,561
3/1/2010	1,168,255	870,118	1,753,612	62,224	3,854,211
4/1/2010	860,052	816,243	2,027,417	56,228	3,759,939
5/1/2010	1,021,582	916,372	2,096,060	56,866	4,090,880
6/1/2010	1,497,680	1,103,182	2,203,507	60,007	4,864,376
7/1/2010	1,738,366	1,178,746	2,109,886	61,940	5,088,939
8/1/2010	1,802,171	1,197,812	2,059,636	62,182	5,121,801
9/1/2010	1,665,666	1,178,444	2,150,916	59,280	5,054,306
10/1/2010	1,338,682	1,089,533	2,135,559	60,215	4,623,990
11/1/2010	960,443	939,443	2,157,946	57,647	4,115,479
12/1/2010	1,048,279	884,015	2,014,037	57,360	4,003,691
1/1/2011	1,381,746	943,292	1,991,009	61,360	4,377,407
2/1/2011	1,300,903	911,354	2,149,323	60,362	4,421,942
3/1/2011	992,400	894,513	1,959,829	59,756	3,906,498
4/1/2011	930,927	899,532	2,131,366	59,250	4,021,075
5/1/2011	1,088,384	928,515	2,160,145	57,421	4,234,465
6/1/2011	1,479,611	1,080,414	2,148,263	60,743	4,769,031
7/1/2011	1,753,077	1,163,121	2,249,398	61,535	5,227,131
8/1/2011	1,699,796	1,163,059	2,379,774	64,760	5,307,388
9/1/2011	1,686,830	1,192,582	2,310,619	66,724	5,256,754
10/1/2011	1,216,781	1,031,298	2,242,136	61,952	4,552,167
11/1/2011	889,899	884,048	2,181,765	57,215	4,012,927

12/1/2011	1,010,759	879,499	2,211,526	59,573	4,161,357
1/1/2012	1,184,341	916,312	2,221,892	62,767	4,385,312
2/1/2012	976,468	865,796	2,191,311	61,202	4,094,778
3/1/2012	937,649	885,876	2,208,271	60,419	4,092,216
4/1/2012	947,266	910,348	2,254,453	60,488	4,172,556
5/1/2012	1,068,155	964,145	2,225,076	59,246	4,316,622
6/1/2012	1,483,468	1,124,001	2,371,260	63,465	5,042,195
7/1/2012	1,653,125	1,165,556	2,276,747	64,187	5,159,616
8/1/2012	1,644,084	1,164,169	2,282,967	66,309	5,157,528
9/1/2012	1,519,527	1,122,289	2,130,745	65,144	4,837,704
10/1/2012	1,247,115	1,046,879	2,081,486	64,127	4,439,606
11/1/2012	951,378	929,933	2,210,211	58,119	4,149,641
12/1/2012	970,793	881,961	2,135,383	57,659	4,045,796
1/1/2013	1,239,178	934,099	2,287,472	64,109	4,524,858
2/1/2013	1,037,088	868,703	2,194,945	65,150	4,165,886
3/1/2013	995,157	869,926	2,094,173	63,078	4,022,334
4/1/2013	905,808	859,908	2,231,557	60,230	4,057,503
5/1/2013	914,217	897,051	2,304,183	62,540	4,177,989
6/1/2013	1,343,257	1,064,993	2,384,889	63,964	4,857,103
7/1/2013	1,639,042	1,171,257	2,278,176	64,380	5,152,855
8/1/2013	1,617,130	1,144,833	2,274,144	63,429	5,099,537
9/1/2013	1,603,942	1,187,187	2,396,925	65,511	5,253,565
10/1/2013	1,373,950	1,113,313	2,211,120	64,016	4,762,399
11/1/2013	947,443	941,621	2,173,176	60,360	4,122,600
12/1/2013	1,121,259	927,562	2,208,618	61,890	4,319,328
1/1/2014	1,456,184	988,020	2,233,409	66,637	4,744,251
2/1/2014	1,436,993	968,116	2,240,145	64,724	4,709,977
3/1/2014	1,094,468	902,740	2,076,529	63,859	4,137,596
4/1/2014	898,370	882,745	2,349,036	63,522	4,193,673
5/1/2014	979,025	933,056	2,343,315	61,853	4,317,250
6/1/2014	1,298,794	1,062,598	2,388,029	65,675	4,815,096
7/1/2014	1,567,099	1,153,136	2,467,752	65,207	5,253,194
8/1/2014	1,556,573	1,141,209	2,511,980	64,727	5,274,489
9/1/2014	1,553,712	1,159,052	2,506,819	65,986	5,285,570
10/1/2014	1,255,691	1,069,587	2,465,828	60,728	4,851,834
11/1/2014	1,008,273	976,516	2,413,650	62,116	4,460,555
12/1/2014	1,041,890	904,408	2,399,251	63,733	4,409,282
1/1/2015	1,258,340	942,169	2,426,296	65,842	4,692,647
2/1/2015	1,230,047	924,813	2,356,571	65,734	4,577,166
3/1/2015	1,196,963	941,589	2,117,129	67,880	4,323,562
4/1/2015	917,579	901,724	2,253,131	64,313	4,136,747
5/1/2015	1,014,654	952,547	2,350,362	62,790	4,380,354

6/1/2015	1,342,555	1,070,967	2,486,836	68,691	4,969,050
7/1/2015	1,646,112	1,186,064	2,526,341	67,560	5,426,077
8/1/2015	1,854,193	1,271,242	2,664,070	70,444	5,859,948
9/1/2015	1,547,044	1,183,825	2,629,681	65,945	5,426,495
10/1/2015	1,227,186	1,062,426	2,378,126	63,962	4,731,700
11/1/2015	958,111	960,782	2,394,040	64,773	4,377,707
12/1/2015	935,912	895,950	2,536,953	65,455	4,434,270
1/1/2016	1,166,831	925,874	2,510,626	67,394	4,670,725
2/1/2016	1,130,914	890,826	2,445,341	74,080	4,541,161
3/1/2016	910,786	879,537	2,423,271	67,107	4,280,701
4/1/2016	822,582	858,217	2,579,768	66,065	4,326,632
5/1/2016	947,137	927,137	2,438,960	67,859	4,381,093
6/1/2016	1,297,706	1,044,764	2,645,768	70,638	5,058,877
7/1/2016	1,672,041	1,187,467	2,569,486	72,000	5,500,994
8/1/2016	1,622,890	1,176,235	2,648,915	71,982	5,520,022
9/1/2016	1,575,457	1,169,899	2,498,810	74,626	5,318,791
10/1/2016	1,375,286	1,114,239	2,506,127	70,304	5,065,956
11/1/2016	1,023,780	984,284	2,463,271	65,818	4,537,153
12/1/2016	965,286	901,610	2,233,601	66,345	4,166,842
1/1/2017	1,167,867	925,152	2,578,889	69,888	4,741,795
2/1/2017	935,695	864,103	2,438,688	66,086	4,304,572
3/1/2017	892,749	879,445	2,296,454	67,190	4,135,838
4/1/2017	919,111	899,876	2,713,117	66,937	4,599,041
5/1/2017	1,003,096	938,864	2,626,494	66,049	4,634,502
6/1/2017	1,230,741	1,028,881	2,734,606	70,301	5,064,530
7/1/2017	1,505,955	1,117,721	2,600,064	74,814	5,298,554
8/1/2017	1,539,948	1,134,881	2,696,478	71,495	5,442,801
9/1/2017	1,473,406	1,139,257	2,717,022	71,875	5,401,560
10/1/2017	1,333,600	1,101,053	2,659,150	70,535	5,164,339
11/1/2017	1,018,878	979,619	2,558,466	67,441	4,624,404
12/1/2017	1,013,617	908,593	2,644,273	67,504	4,633,987

Prior Load Forecast Evaluation

Table 4: Energy Forecasted vs Actual

Sales (GWh)	2015	2016	2017
Previous IRP Sales Forecast (BP15)*	58,829	61,281	64,654
Weather Normalized Actual Sales	56,801	57,287	58,782
Deviation	2,028	3,993	5,872
% Deviation	3%	7%	9%

Table 5: Peak Forecasted vs Actual

Peaks (MW)	2015	2016	2017
Previous IRP Sales Forecast (BP15)*	9,869	10,081	10,495
Weather Normalized Actual Peaks	9,640	9,908	10,317
Deviation	229	173	178
% Deviation	2%	2%	2%

Causes of Significant Deviations Between Forecasts and Actuals

Industrials

The sales levels forecasted as part of the previous IRP were generally higher than weather normalized actuals, with the majority of the differences coming from the industrial class. At the time of this forecast development in 2Q2014, oil prices were high (near \$100/bbl.) and there were a number of large industrial expansion projects and other new large industrial projects expressing interest in the ELL area. This was expected to have knock-on effects for residential and commercial electricity consumption as well. Shortly thereafter, oil prices began a steep decline during 2014 and further into early 2016 before prices leveled off in the low \$40/bbl. range through 2017. As a result, a number of the large industrial projects were either delayed or cancelled, thereby causing electricity consumption to be lower than forecasted levels.

Energy Efficiency

In addition, during this time, there were a number of advancements in energy efficiency that resulted in lower electricity consumption. These advancements include the proliferation of efficient LED bulbs at lower prices and in warmer colors than the older, blue-hued LEDs. These cut significantly into both the residential and commercial sales.

Also, new commercial refrigeration standards as well as new residential water heater standards went into effect during this time (2015-2017), resulting in lower than expected electricity consumption.

Economics

Additionally, the commercial sales forecast model used for the previous IRP included an economic variable called Gross State Product (GSP) which is akin to a state-level GDP. The outlook for GDP was positive and optimistic; however, during 2016 and 2017, it was noted that the trending relationship between electricity consumption and economic output was breaking down, largely due to energy efficiency becoming more prevalent and due to the recent shift from an energy-intensive manufacturing economy to a less energy-intensive services-based economy.

Electrification Projects

The previous IRP forecast included a greater amount of expected sales growth from electrification projects such as conversions of diesel pumps to electric pumps and conversions of gas-powered forklifts to electric-powered forklifts. These types of conversions became less attractive as oil prices declined. The levels of conversions included in the current IRP forecast are now lower.

Peaks

All of the above factors which affected the sales forecast also had an effect on the peak forecasts; however it is believed that the effects of energy efficiency have affected sales projections and resulting variances more than peaks.

Explanations of revisions applied to subsequent forecasts to adjust for deviations

As a result of the factors noted above, there have been a number of modifications to the sales forecast models since the previous IRP forecast to adjust for previous forecast deviations. Those adjustments include:

- Taking a more conservative approach to adding new large industrial customers or industrial expansion projects to the sales forecast – The current forecast process uses higher thresholds for new project inclusion and risk-adjusts the expected increases in electricity volume for these projects.
- Removal of knock-on effects for Residential and Commercial from new Large Industrial projects – While it is reasonable to assume that a new petrochemical facility in an area will result in more residential and commercial

customers in that area, these knock-on effects have been removed from the current forecast process due to the uncertainty around timing and magnitude of realizing this type of additional growth.

- Inclusion of explicit DSM decrements – The current forecast employs an add-back method for estimating the effects of DSM on future electricity consumption. This method allows ELL to better assess the levels of its DSM programs in the future and the effects on the forecasts.
- Removal of GSP as an economic variable – As mentioned previously, due to the decoupling of electricity consumption from economic output and due to the volatility in the economic forecasts, this variable has been removed from the commercial forecast models.

The current peak load forecast uses historical hourly load data settled through the MISO market as an input. In addition, as the company has more history with the Algiers load excluded from ELL's load, the historical data will better represent future load levels.

Explanation of the effects of DSM programs, interruptible loads, or other factors on the prior load forecast

ELL's DSM programs started in 2014 and were relatively small at the time. In the previous IRP forecast, there was no adjustment for these programs.

The sales and load forecasts are based on historical levels of electricity consumption and therefore inherently include the effects of load that was interrupted. ELL also prepares a firm load forecast that includes assumptions for interruptible load.

Load Forecast




Table 7: Summer Coincident Peaks (MW) Forecast


	Residential	Commercial	Industrial	Governmental	Company Use	Wholesale	Total
2019	3,574	2,386	3,877	144	22	129	10,133
2020	3,546	2,381	4,061	148	22	129	10,288
2021	3,531	2,354	4,080	150	23	129	10,267
2022	3,531	2,328	4,107	152	23	129	10,270
2023	3,540	2,317	4,155	155	23	129	10,319
2024	3,541	2,321	4,229	159	23	129	10,401
2025	3,541	2,325	4,248	162	23	129	10,428
2026	3,554	2,322	4,269	164	23	129	10,461
2027	3,575	2,313	4,289	166	23	129	10,495
2028	3,603	2,300	4,310	168	23	129	10,533
2029	3,624	2,303	4,336	171	23	129	10,586
2030	3,616	2,305	4,349	174	23	129	10,595
2031	3,618	2,310	4,369	177	23	129	10,625
2032	3,633	2,302	4,395	179	23	129	10,660
2033	3,655	2,291	4,419	180	23	129	10,696
2034	3,674	2,288	4,440	183	23	129	10,737
2035	3,699	2,291	4,468	186	23	129	10,795
2036	3,690	2,305	4,473	190	23	129	10,809
2037	3,707	2,305	4,493	192	23	129	10,849
2038	3,727	2,298	4,514	194	23	129	10,885


Table 8: Winter Coincident Peaks (MW) Forecast


	Residential	Commercial	Industrial	Governmental	Company Use	Wholesale	Total
2019	3,242	1,930	4,019	154	16	129	9,490
2020	3,072	1,943	4,148	156	17	129	9,466
2021	3,066	1,939	3,970	159	17	129	9,280
2022	2,997	1,915	4,090	164	17	129	9,312
2023	3,017	1,896	4,171	168	16	129	9,398
2024	3,194	1,888	4,335	169	16	129	9,731
2025	3,103	1,812	4,254	170	16	129	9,484
2026	3,085	1,921	4,224	174	17	129	9,551
2027	3,090	1,927	4,241	177	17	129	9,581
2028	3,050	1,900	4,328	183	16	129	9,606
2029	3,046	1,898	4,361	182	16	129	9,633
2030	3,225	1,897	4,457	186	16	129	9,911
2031	3,131	1,825	4,378	187	16	129	9,666
2032	3,104	1,936	4,350	191	17	129	9,728
2033	3,043	1,925	4,404	195	17	129	9,714


(Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan)


2034	3,065	1,911	4,464	200	16	129	9,785
2035	3,063	1,909	4,496	199	16	129	9,813
2036	3,159	1,838	4,485	201	16	129	9,828
2037	3,143	1,945	4,451	205	17	129	9,891
2038	3,148	1,953	4,468	208	17	129	9,923














Table 10: Annual Load Factor Forecast

	Residential	Commercial	Industrial	Governmental	Company Use	Wholesale	Total
2019	48%	58%	93%	71%	59%	51%	68%
2020	48%	58%	94%	70%	59%	51%	69%
2021	48%	58%	93%	71%	59%	51%	69%
2022	47%	58%	93%	71%	59%	51%	69%
2023	47%	59%	93%	71%	59%	51%	69%
2024	48%	58%	93%	71%	59%	51%	69%
2025	48%	58%	94%	71%	59%	51%	69%
2026	48%	58%	94%	71%	59%	51%	69%
2027	48%	59%	94%	71%	59%	51%	69%
2028	48%	59%	94%	72%	59%	51%	69%
2029	47%	59%	94%	72%	59%	51%	69%
2030	48%	59%	94%	71%	59%	51%	70%
2031	48%	59%	94%	71%	59%	51%	70%
2032	48%	59%	94%	72%	59%	51%	70%
2033	47%	60%	94%	72%	59%	51%	70%
2034	47%	60%	94%	72%	59%	51%	70%
2035	47%	60%	94%	72%	59%	51%	70%
2036	48%	60%	95%	72%	59%	51%	70%
2037	48%	60%	95%	72%	59%	51%	70%
2038	48%	60%	95%	72%	59%	51%	70%

Appendix B Response to Stakeholder Comments

Comments Regarding Deactivation and Retirement Assumptions or Evaluations

<p>Staff requests that when the Company files its Draft IRP, a confidential version of the Draft IRP that includes a detailed discussion of the assumptions behind the Company's deactivations decisions, including any subjective decisions made in the assumptions, be made available to Staff and Stakeholders who have signed confidentiality agreements in this Docket. Pages 11 and 12 of the "2018_0614 Staff Comments" document.</p> <p>LEUG requests that Entergy provide, in its Draft IRP Report, "expected retirement date for any resource expected to retire within the next ten years, and an explanation of the reason for the retirement". Page 9 of the "2018_0614 LEUG Comments" document.</p> <p>AAE noted that the Company did not identify any generating assets within its fleet that would be considered for deactivation. Page 3 of the "2018_0614 Alliance Comments" document.</p>	<p>Please see Section: Existing Fleet Deactivation Assumptions.</p>
<p>ELL's analysis should include transmission as an alternative to additional generation resources and the IRP Report should detail how this analysis was performed. Page 14 of the "2018_0614 Staff Comments" document.</p>	<p>The generation portfolio design included in the IRP document is based primarily on ELL's projected capacity needs. As mentioned in Section: Legacy Gas Useful Life Assumptions and ELL's Action Plan, ELL will perform an economic analysis of its legacy fleet, which will support or identify necessary changes to deactivation assumptions. The results of this detailed analysis will provide some insight regarding where new generation may need to be sited, as well as whether transmission enhancements may be a viable alternative to additional generation.</p> <p>Please see Section: Transmission Planning.</p>
<p>Sierra Club infers that an IRP process is the</p>	<p>Throughout the planning period all ELL owned</p>

appropriate time for ELL to "rigorously investigate the risk that its coal-fired power plants pose to its ratepayers". Page 2 of the "2018_0614 Sierra Club Comments" document.

Sierra Club recommends that ETR should present a scenario specifically evaluating the costs and benefits of retiring ETR's coal-fired units. Page 4 of the "2018_0614 Sierra Club Comments" document.

Sierra Club recommends that ETR should present a detailed financial analysis of the costs of continuing to operate each of its coal-fired units, including an analysis of each unit's total production costs compared to its operational revenues. Page 4 of the "2018_0614 Sierra Club Comments" document.

Sierra Club recommends that ELL should use consistent retirement assumptions across its IRP processes in AR and LA. In particular, the Company should, as it has indicated in AR, assume in its reference case the retirement of WB and IS in 2028, 2030, respectively. The Company should include a scenario or sensitivity evaluating those retirements even earlier, in addition to the retirement of NL6 in the mid- to late-2020's. Page 6 of the "2018_0614 Sierra Club Comments" document.

coal units (Nelson 6 and Big Cajun 2 Unit 3) are assumed to continue to operate. These units will continue to operate as long as it is in the customers' best interest to do so, while considering the long-term planning objectives of cost, reliability and risk. ELL continues to monitor key market drivers and their effects on ELL's generation portfolio, including the coal units. Entergy's point of view on future carbon emission pricing is included in the analysis.

Additionally, within the evaluation, White Bluff and Independence (resources which ELL has a life-of-unit PPA) are assumed to deactivate in 2027 (White Bluff Unit 1), 2028 (White Bluff Unit 2) and 2030 (Independence Unit 1). These assumptions are consistent with the assumed deactivation schedule at the time the analysis was complete.

<p>Sierra Club recommends that ELL should allow the model to determine unit retirements decisions endogenously. Page 4 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that such retirement decisions should be made in the context of portfolio replacement options, rather than single one-off replacement assumptions (i.e., a single natural gas combined cycle (“NGCC” unit) to capture least-cost resource options. Page 6 of the “2018_0614 Sierra Club Comments” document.</p> <p>SWEA recommends that ELL should verify that the AURORA software and its methodologies will be used to identify potential generation units for retirement. Page 1 of the “2018_0614 SWEA Comments” document.</p>	<p>AURORA has the capability to assess deactivations in the capacity expansion algorithm, but there are data requirements which make this impractical within the scope of an IRP analysis. Assessments would be required for each unit and each potential deactivation date for that unit to determine the capital and O&M spending each year needed to maintain the unit from the beginning of the study period through each potential deactivation date. Furthermore, if unit availability or other attributes are dependent on the deactivation date, then estimates and assumptions would need to be developed to reflect changes in those attributes. The magnitude and timing of potential investments required to maintain a plant in excess of routine operating & maintenance expenses are uncertain and difficult to forecast, especially as units reach the end of their useful lives. Specific analyses are performed for such units when events (e.g., major component failures) trigger the need for such investments or when sustainability investments are required to operate the unit long-term. Additionally, generally it is a reasonable assumption to expect maintaining an existing operating plant will be lower cost to customers than building a new generating facility, unless circumstances around the cost to maintain the facility, market conditions, or policy changes dictate a more detailed evaluation.</p>
<p>SWEA recommends that ELL should comment on the finalized MTEP19 retirement assumptions, and unit-specific information, as it relates to its own scenario-building process. Page 1 of the “2018_0614 SWEA Comments” document.</p> <p>SWEA recommends that ELL should fully utilize MISO’s future assumptions for its IRP, and retirement assumptions. Page 11 of the “2018_0614 SWEA Comments” document.</p>	<p>ELL designed the presented futures to reasonably bound possible outcomes and to provide a reasonable outlook on a range of potential market prices. ELL sees no reason to limit its IRP assumptions to those made in the MTEP process.</p>

Comments Regarding Energy Efficiency and DSM

<p>AEMA provided "benchmarking" analysis that suggests that MISO's DR penetration, on average, is triple that of Entergy's. Pages 12 and 13 of the "2018_0614 AEMA Comments" document.</p> <p>AEMA provided "benchmarking" analysis that suggests that Peer utilities, with reasonably similar C&I DR programs, have two to five times the C&I DR penetration as Entergy. Pages 13 and 14 of the "2018_0614 AEMA Comments" document.</p> <p>AEMA provided "benchmarking" analysis that suggests that based on DR supply curves produced for Xcel Energy, Entergy's C&I DR potential could exceed 1 GW. Pages 14 to 16 of the "2018_0614 AEMA Comments" document.</p>	<p>The purpose of the DSM study is to evaluate the potential growth of Demand Response and Energy Efficiency programs when compared to the Current Programs, as defined in the Draft IRP Report.</p>
<p>Staff noted that the ICF DSM Presentation explains that "current energy efficiency programs... were modeled largely based on current program designs, but with expanded budgets". Staff also notes that data supporting this statement has not been provided, "leaving Staff entirely unable to understand how, and to what extent, Existing Demand-Side Resources have been modeled". Page 13 of the "2018_0614 Staff Comments" document.</p>	<p>Supporting data for this is included in ICF's report for the draft IRP.</p>
<p>Sierra Club recommends that ETR should use energy efficiency assumptions that are consistent with its approach in AR. Pages 20 and 21 of the "2018_0614 Sierra Club Comments" document.</p> <p>Sierra Club recommends that all of model runs should have Entergy meet any mandated energy efficiency DSM goals. Pages 20 and 21 of the "2018_0614 Sierra Club Comments"</p>	<p>ELL's Energy Efficiency program is conducted pursuant to the Louisiana Public Service Commission's Quick Start Energy Efficiency Rules, which were issued in LPSC General Order No. R-31106, dated September 30, 2013. In particular, Section VI of the EE Rules established a range for each participating utility's energy efficiency budget of 0.25 - 0.5% of 2012 retail revenues, adjusted for Industrial Opt-Outs and the \$75 per month cap. Exceeding this cap could potentially put</p>

<p>document.</p> <p>AAE urged the Commission and the Company to "fully exploit this largely untapped affordable energy resource (Energy Efficiency) in the IRP. Page 4 of the "2018_0614 Alliance Comments" document.</p>	<p>any expenses over 0.50% at risk for regulatory recovery. ELL continues to participate in the Commission's energy efficiency rulemaking and has filed comments in Phase II rulemaking of this docket in support of expanding the energy efficiency budget cap up to 1% of ELL's retail revenues.</p> <p>ELL's Draft IRP analysis included the Program Year 2 (2015-2016) energy efficiency programs at the Year 2 budgets as a starting point, an expansion of those programs, and new programs for selection in each portfolio. In total, these options add up to forecasted energy savings of up to 4x ELL's Program Year 2 savings.</p>
<p>Sierra Club recommends that ETR should disclose the costs of energy efficiency to be assumed for this IRP and provide the underlying assumptions. Pages 20 and 21 of the "2018_0614 Sierra Club Comments" document.</p>	<p>The energy efficiency costs were included in the DSM potential study stakeholder presentation posted to ELL's website. The underlying assumptions will be provided as part of the draft IRP in ICF's final report.</p>
<p>Sierra Club recommends that ETR should develop a supply curve for energy efficiency; the development of the supply curve should be disclosed for the Commission and stakeholders. Pages 20 and 21 of the "2018_0614 Sierra Club Comments" document.</p>	<p>Energy efficiency supply curves were not developed by ELL because the evaluation of the potential DSM programs (energy efficiency and demand response) was performed using the AURORA model including inputs from the ICF DSM study that, in addition to supply curve considerations, takes into account each DSM program's load shape, ELL's hourly load shape, and hourly energy prices.</p>
<p>Sierra Club recommends that ETR should model efficiency as a resource and using the utility cost method. Pages 20 and 21 of the "2018_0614 Sierra Club Comments" document.</p>	<p>EE is included as a resource with a 20-year load shape and levelized cost. The utility cost method was one of the four standard tests calculated and applied by ICF in its modeling approach.</p>

Comments Regarding the Evaluation Process

<p>AAE urges the Commission to confirm that ELL is in fact fully and accurately evaluating</p>	<p>Elements of the market are implicitly included in the 'optimal' portfolio mixes for each future</p>
--	--

<p>purchasing power from the MISO market, especially while prices are currently low. Page 2 to 3 of the “2018_0614 Alliance Comments” document.</p> <p>Staff requests ELL to explicitly describe how participation in the MISO marketplace may provide alternatives to ELL generation projects and whether elements of the market are included in the optimal portfolio mix. IRP requirements on this topic can be found in sections 5(d) and 6(a). Page 14 of the “2018_0614 Staff Comments” document.</p> <p>Staff requests ELL to ensure that all resources available to ELL through the MISO system are included and evaluated. Page 15 of the “2018_0614 Staff Comments” document.</p>	<p>by virtue of the modeling methodology laid out in the assumptions presentation. Market LMPs (Locational Marginal Prices) are calculated based on the varying fundamental and market assumptions in each future - portfolio choices are influenced by these market prices.</p> <p>However, while ELL recognizes the benefits of participating in MISO through its long-term planning, it is important to note that participation in MISO does not change the responsibilities of an LSE to ensure-reliable, economic electric service for its customers, which requires long-term planning. Consistent with this responsibility, ELL's long-term planning reserve margin target is consistent under each future (12% ICAP RM (Installed Capacity Reserve Margin) on NCP (Non-coincident Peak) does not vary). See Section: Resource Adequacy and Planning Reserve Requirements.</p>
<p>Staff requests ELL to include information detailing how excess capacity available through MISO and potential purchase power agreements were considered as available alternative resources in the Company's analysis. Pages 14 and 15 of the “2018_0614 Staff Comments” document.</p>	<p>Excess capacity available through MISO is not guaranteed long-term and partially a function of proactive planning actions of regulated utilities such as ELL. Accordingly, excess market capacity is not considered as an option for meeting long-term planning objectives such as the reserve margin. Resource alternative inputs to the model are developed from a financial perspective assuming utility ownership. However, the type and timing of capacity is what the model is solving for, not the optimal ratio of PPA/ownership. The portfolios are indicative of what types of resources would be preferred under certain conditions. The decision to procure said resources would occur through competitive solicitations consistent with the Market Based Mechanisms Order (“MBMO”) and may include self-build alternatives as well as PPAs.</p>
<p>Staff requests that, should ELL exercise its option to “screen out of evaluation certain viable resource alternatives,” ELL is to fully explain the basis of the exclusion from evaluation in accordance with IRP Rules. Page</p>	<p>See Section III of the IRP.</p>

<p>16 of the “2018_0614 Staff Comments” document.</p>	
<p>AAE suggests that AURORA has "significant shortcomings" and that the Commission and ELL "acknowledge these shortcomings and ensure verifiable steps are taken to optimize for the utilization of low-cost energy from renewable and demand side resources.” Page 9 of the “2018_0614 Alliance Comments” document.</p> <p>SWEA recommends that ELL should develop a study detailing various benefits and limitations of its current modeling software. Page 11 of the “2018_0614 SWEA Comments” document.</p>	<p>ELL adopted AURORA for long-term energy price forecasting and production costing in 2013 and has used AURORA for several resource certifications and IRPs that were accepted by the LPSC. ELL regularly reviews the software alternatives available to meet its long-term energy price forecasting and production costing needs and currently it has determined that AURORA best meets those needs.</p>
<p>SWEA noted that EAI representatives suggested that AURORA was addressing capacity shortages in the afternoon/evening by “building gas technologies rather than renewables, even if its first preference is renewables”. ELL should work to identify solutions to the aforementioned problem with the AURORA dispatch model. Page 13 of the “2018_0614 SWEA Comments” document.</p>	<p>Please see Table 10: Renewable Modeling Assumptions and Section: Solar Capacity Credit Modeling for more information on assumptions and methodology used for solar and wind generation.</p> <p>The AURORA model reasonably evaluated all resource alternatives and their corresponding benefits to meeting capacity and energy requirements. The approach outlined in the IRP resulted in a wide range of the amount of renewable additions between the portfolios (1 GW (Portfolio 2) to 7.5 GW (Portfolio 4) on an installed capacity basis).</p>
<p>API recommends that ETR use a neutral approach regarding fuel and technology when planning for the use of more newer energy resources that would provide for more flexibility, reliability, and cleaner energy. Pages 5 and 6 of the “2018_0614 API Comments(2)” document.</p>	<p>ELL's approach to fuel and technology is neutral in that it seeks to identify the benefits and drawbacks of each generation technology in a non-preferential manner. Recognizing the fuel diversity benefits of zero variable cost resources is part of a neutral approach, as is recognizing the dispatchable nature/benefits of gas resources.</p>

Comments Regarding LPSC IRP Rules and Entergy Policy

<p>Staff and stakeholders found that it was</p>	<p>Though not officially labeled as an “IRP</p>
---	---

<p>important for ELL to update its load projections and allow the Commission the opportunity to monitor the projections. Staff encouraged ELL to file updated IRP Reports as conditions and ultimately resource plans change. Staff, however, is unaware of any updates filed the Company. Page 10 of the “2018_0614 Staff Comments” document.</p>	<p>Update” in ELL’s IRP docket, ELL provided the Commission and Intervenors with updates to the assumptions used in the IRP and any changes to ELL’s resource plan in other docketed proceedings. For example, ELL provides its current load forecasts on a quarterly basis in LPSC Docket U-32675 and also provided updated load and capability analyses in conjunction with certifications associated with LCPS, SCPS, WPEC, Oxy, Carville, etc. ELL is aware of Staff’s recommendation and intends to provide updates to its IRP when/if conditions and/or plans change significantly such that an update is warranted.</p>
<p>Staff recommends that ELL review Sections 5(b) and 8(c) of the IRP Rules, and that the Company’s Draft IRP include a detailed discussion of each Existing Supply-Side Resources topic listed in the IRP Rules. For example, these discussions should include: description of the conditions, ownership information, and location of all the Company’s Existing Supply-Side Resources. Page 12 of the “2018_0614 Staff Comments” document.</p>	<p>See Section II of the Draft IRP report.</p>
<p>Staff recommends that ELL "review the IRP Rules" and that the Company's Draft IRP include a detailed Existing Resource Evaluation, including a discussion of the development and incorporation of each data assumption related to Existing Supply-Side Resources, Existing Demand-Side Resources, and Existing Transmission System topics listed in the IRP Rules. Refer to sections 3(b), 6(a) and 6(b) for a description of existing resources that are to be evaluated and provides guidelines for their evaluation. Page 15 of the “2018_0614 Staff Comments” document.</p> <p>Staff requests that the Company fully document and explain all data assumptions, including how and why those assumptions were developed and used to analyze viable</p>	<p>See Section II of the Draft IRP report.</p>

<p>resource alternatives in a technical appendix to the Company's Draft IRP Report. Page 16 of the "2018_0614 Staff Comments" document.</p>	
<p>LEUG requests that Entergy provide, in its Draft IRP Report, "some measure of rate impacts for the reference plan and the alternative resource planning scenarios evaluated". Page 9 of the "2018_0614 LEUG Comments" document.</p>	<p>See Table 14 of this Draft IRP for the present value of each portfolio's cost in each modeled future. This table is intended to provide the best available estimate of overall portfolio cost given the long-term nature of the IRP process and the fact that customer class bill and rate effects will be determined through certification proceedings associated with particular resources.</p>
<p>LEUG requests that Entergy not use the IRP to circumvent the MBMO. Pages 10 to 12 of the "2018_0614 LEUG Comments" document.</p>	<p>The LPSC Corrected General Order for Docket No. R-30021: <i>In Re: Development and Implementation of Rule for Integrated Resource Planning for Electric Utilities</i> ("IRP Docket") states beginning on page 2, "The goal of the IRP is to develop a defined resource plan, and the Action Plan is intended to specify implementing actions that the utility should take, however Staff recognizes that these rules are not intended to replace or modify the normal docketed resource certification process, and a statement to this effect is included in the Action Plan section."</p> <p>In its previous IRP cycle, and as required by the IRP Docket rules, ELL utilized the normal docketed resource certification process, including the requirements of the MBMO, for certification of the resources identified in the Action Plan that ELL chose to pursue. ELL intends to continue to follow the rules as outlined in the IRP Docket and comply with all relevant Commission orders.</p>
<p>AAE asserts that ENO and EAI provided more of an opportunity for stakeholders to develop "their own modeling inputs" with regards to DSM. Pages 3 and 4 of the "2018_0614 Alliance Comments" document.</p>	<p>ELL will take this feedback into consideration in planning its next IRP cycle.</p>
<p>Sierra Club recommends that ETR should make all underlying data and inputs available in electronic, unprotected formats, and</p>	<p>ELL has posted its publicly available initial IRP data assumptions, responses to stakeholder questions, and supplemental data assumptions</p>

<p>preferably available through the Company’s publicly available website or a cloud-based website. Page 23 of the “2018_0614 Sierra Club Comments” document.</p>	<p>on its public website at http://www.entropy-louisiana.com/irp/2019_irp.aspx. ELL does not intend to make native files available on a publicly available or cloud-based website.</p>
<p>Sierra Club recommends that ETR should provide documentation for historical data and other data and assumptions that are enumerated in the LPSC order. Page 23 of the “2018_0614 Sierra Club Comments” document.</p>	<p>Please refer to Appendix A for this information.</p>
<p>Sierra Club recommends that ETR should also provide for an informal discovery process and make its responses to discovery requests available through its publicly accessible website. Page 23 of the “2018_0614 Sierra Club Comments” document.</p>	<p>Staff’s report (2018_0525 Report of Stakeholder Mtg_Notice of Extension.pdf) states clearly that "As a robust IRP schedule is set forth in Section 10 of the Commission's IRP Rules and formal discovery is not part of those procedures, no formal discovery will be allowed herein." Given that, ELL asserts that the opportunities for stakeholders candid participation in technical conferences and offering comments to which ELL may respond is indeed an informal discovery process.</p>
<p>SWEA recommends that ELL should conduct a study of corporate renewable energy procurement practices by other utilities and states. This study should include best practices, estimated corporate interest within the ELL footprint, and recommendations for an action plan (reference to a Green Tariff). Pages 11 to 12 of the “2018_0614 SWEA Comments” document.</p> <p>AAE suggests that ELL should consider a Green Tariff, “from residential to large industrial,” contemplated within its IRP. Page 5 of the “2018_0614 Alliance Comments” document.</p>	<p>ELL is actively engaged in studying and understanding its customers’ needs including "corporate interest." On September 14, 2018, ELL filed the Experimental Renewable Option Tariff in response to its large commercial and industrial customers’ interest in being powered by additional renewable energy sources to meet its corporate sustainability and renewable objectives. Furthermore, ELL intends to continue to contemplate a variety of offerings that meet its customers’ needs while providing service at the lowest reasonable cost to its customers.</p>

Comments Regarding Model Inputs and Data Assumptions

<p>Staff requests that the Company's Draft IRP include detailed documentation on the background and reasons for how the Company</p>	<p>See Sections II and III of the Draft IRP report for a variety of discussions regarding data</p>
---	--

<p>developed each of its data assumptions as well as how those data assumptions were then utilized in the Company's modeling efforts, and why they were utilized in the manners selected. Pages 9 and 10 of the "2018_0614 Staff Comments" document.</p>	<p>assumptions.</p>
<p>Staff requests that ELL include a functional description of its current and projected ELL transmission network topology, MISO's planning projects for transmission, ELL operations within MISO system-wide planning, and that the transmission network topology be used in identifying needs in accordance with Section (8)(d)(iv) of the IRP Rules. Page 13 of the "2018_0614 Staff Comments" document.</p> <p>LEUG requests that Entergy, in its Draft IRP Report, identify whether its IRP modeling assumptions include all transmission reliability and congestion projects that have been approved by MISO, including the "DSG-6" congestion project that was approved by MISO for SE LA as part of its 2016 congestion study process as an "Other" project but which has not yet been submitted by Entergy to the LPSC for certification approval. Page 10 of the "2018_0614 LEUG Comments" document.</p>	<p>The analysis performed for the resource portfolio design included in the IRP document is based primarily on evaluating ELL's projected capacity needs and targeted resource mix and does not consider Transmission topology at this stage in long-term resource planning. Other analyses which are part of ongoing planning processes, such as for the siting of specific future generation resources, will take into account transmission planning, and will apply the Transmission topology in the AURORA Network Nodal Model, and will include approved MISO MTEP projects.</p>
<p>Staff requests that ELL provide additional details on the development of data assumptions related to demand and energy growth projections. Page 15 of the "2018_0614 Staff Comments" document.</p>	<p>See Section Load Forecasting Methodology and Appendix A of the IRP.</p>
<p>Oxy stated that while ELL's May 31, 2018 Data Assumptions included Oxy as a resource, the June 1, 2018 Data Assumptions Supplement excluded Oxy as a resource. Pages 1 to 3 of the "2018_0614 Oxy Comments" document.</p> <p>LEUG notes that ELL "inadvertently" omitted</p>	<p>Although it was inadvertently omitted from the June 1, 2018 Data Assumption Supplement, the Oxy PPA is included as an ELL resource in ELL's IRP analysis.</p>

<p>Oxy PPA as one of its resources in the June 1, 2018 Data Assumptions Supplement filing. Page 13 of the “2018_0614 LEUG Comments” document.</p>	
<p>LEUG requests that Entergy identify and explain the methodology and due diligence process that it uses to project industrial load growth and whether to include projected new or expansion projects in the load forecast. They go on to specify (5) specific questions that should be answered in ELL's analysis. Page 8 of the “2018_0614 LEUG Comments” document</p>	<ol style="list-style-type: none"> 1. The load forecast is based on the expected operating levels of existing large industrial customers as well as analysis of individual project proposals for new or expansion customers. 2. The load forecast takes into account new plants and expansion of existing plants. 3. A project typically has a signed Electric Service Agreement (ESA) in order to be included in the forecast. Further clarification can be found in the response to (4) below. 4. The projects are probability weighted based on each project’s stage of development. A probability is assigned to each project based on: the progress made toward the execution of a contract for electric service or delivery of service, customer actions such as load studies, facilities studies, project funding decisions, public announcements, permits, incentive packages, reimbursement agreements, and executed Electric Service Agreements (“ESAs”), all of which signal progress. Probability assessments are based on the informed judgement of ELL’s industrial customer representatives. The individual probabilities are used to weight each new or expansion project. For example, a project with 70% probability would enter the forecast with 70% of the MW and MWh for the full project. 5. The projects are probability weighted based on each project’s stage of development. A probability is assigned to each project based on: the progress made toward the execution of a contract for electric service or delivery of service, customer actions such as load

	<p>studies, facilities studies, project funding decisions, public announcements, permits, incentive packages, reimbursement agreements, and executed Electric Service Agreements (“ESAs”), all of which signal progress. Probability assessments are based on the informed judgement of ELL’s industrial customer representatives. The individual probabilities are used to weight each new or expansion project. For example, a project with 70% probability would enter the forecast with 70% of the MW and MWh for the full project.</p>
<p>AEMA recommends that the Commission retain an independent third-party consultant to evaluate the DR potential within ELL. Page 3 of the “2018_0614 AEMA Comments” document.</p> <p>AEMA recommends that Entergy use a conservative placeholder of 6% total C&I DR potential in its IRP until the Commission-led study is completed. Page 3 of the “2018_0614 AEMA Comments” document.</p> <p>AEMA recommends that Entergy issue a revised IRP using the results of the new potential study as inputs to its final IRP modeling. Page 3 of the “2018_0614 AEMA Comments” document.</p> <p>AEMA states that one of Entergy's shortcomings with data assumptions is its failure to consider additional curtailable or interruptible DR from C&I customers as a viable alternative resource to new generation. They then go on to suggest that ICF used a "flawed assumption" when they assumed that "all customers could participate in Entergy's existing interruptible tariff, and therefore, that</p>	<p>In light of the Company’s proposed Action Plan in this IRP and other factors as described below, the additional DSM potential study recommended by AEMA is not necessary at this time. Although new interruptible load tariffs were not included in the ICF DSM potential study or the Draft IRP analysis, ELL has committed to develop new interruptible rate schedule options for its customers, as discussed in further detail in the Action Plan of this Draft IRP.</p> <p>The Company’s offering of new interruptible rate schedules will give real data on customer interest in interruptible rates and therefore should eliminate the need for a study of interruptible load potential.</p> <p>Lastly, the Draft IRP results, even without any additional interruptible load modeled, give meaningful insight into the resource planning landscape for ELL over the study period. The Company’s IRP analysis is solving for a resource need of approximately 6.5 GW by 2038, with the first new-build resources not being needed until 2028. Given AEMA’s recommended assumption of an additional 400 MW of interruptible load, the addition of this demand response option in the model would not change ELL’s IRP in a meaningful way.</p> <p>Because the Company has committed to</p>

<p>no incremental potential existed". They then cite that Entergy's existing Interruptible Tariff, which provides the only option for C&I DR, has been closed to new customers since 1999. Pages 8 to 12 of the "2018_0614 AEMA Comments" document.</p>	<p>develop new interruptible load programs, and because the Draft IRP results are useful and not likely to change substantially with the study recommended by AEMA, it is unnecessary to delay the IRP process with the additional demand response potential study and additional IRP analysis recommended by AEMA.</p>
<p>AAE recommends implementing reputable DR programs in the IRP, including TOU and Interruptible Load Programs. Page 4 of the "2018_0614 Alliance Comments" document.</p>	<p>ToU and interruptible load programs were included for residential and commercial customers. ToU was included for industrial customers. See ICF's DSM study for more detail.</p>
<p>AAE recommends that DR measures should "compete" with supply side options by recognizing the "option value". In other words, they recommend that ELL consider the value of DR during "extreme events" and not just under "normally modeled situations". Page 5 of the "2018_0614 Alliance Comments" document.</p>	<p>All resources would have different value under "extreme events" relative to "normally modeled situations."</p>
<p>AAE recommends that DR measures should "compete" with supply side options by recognizing the "option value". In other words, they recommend that ELL consider dispatching DR programs so that they "spread out" load reductions over a broader number of peak hours rather than utilizing them during one peak period. Page 5 of the "2018_0614 Alliance Comments" document.</p>	<p>DSM programs (which include Energy Efficiency and Demand Response) are available for selection within the Capacity Expansion optimization algorithm, and they compete directly with supply-side alternatives. DR programs' load reductions are consistent with the hourly MW reduction provided by ICF, and are dependent on the program type.</p>
<p>AAE urges ELL to consider "all benefits to the system". Specifically, AAE urges ELL to include, in its modeling, the benefits associated with voltage regulation, load following, and contingency reserves. They also recommend that ELL use a "net-cost-of capacity approach, as pioneered by Portland General Electric in its 2016 draft IRP. Page 7 of the "2018_0614 Alliance Comments" document.</p>	<p>Quantifying benefits associated with voltage regulation would likely require transmission modeling and even then, the economic benefit is uncertain (i.e. what is the cost of avoided voltage regulation?). Reserves value can be approximated out of model using historical ancillary market clearing prices to forecast future values. However, these values are historically small and are expected to remain so. In general, the Portland General Electric approach is doable, but these benefits are also site-specific, and the existing modeling construct is zonal in nature.</p>

<p>AAE infers that ELL should consider Lazard’s annual analysis regarding Levelized Cost of Energy (“LCOE”) and incorporate that into its IRP modeling. Pages 7 and 8 of the “2018_0614 Alliance Comments” document.</p> <p>SWEA recommends that ELL use Lazard's analysis as a resource for LCOE Analyses associated with renewable energy and energy storage pricing. Pages 3 to 5 of the “2018_0614 SWEA Comments” document.</p>	<p>Lazard produces capital cost and LCOE/LCOS estimates for generation alternatives and storage. These are roughly consistent with ELL’s internal calculations and external consultant data.</p>
<p>AAE recommends that ELL should be required to provide a detailed accounting of changes it makes to how AURORA performs the optimization modeling to include 1) whether existing resources are fully competing against alternatives (if not, explain), 2) whether potential supply additions are competing directly against the full range of DSM resources, 3) any limitations on allowed market sales from ELL to MISO, 4) any limitations on market purchases from MISO to ELL, 5) any assumptions about the cost and types of new non-ELL resource additions in MISO, 6) any additional costs or constraints placed on renewables above installed cost and generation output, 7) any limitations placed on DR resources. Pages 9 and 10 of the “2018_0614 Alliance Comments” document.</p>	<ol style="list-style-type: none"> 1. The model does not make endogenous retirement decisions. Even if it did, this would require projections of go-forward capital / O&M spend for every unit throughout the planning horizon, which doesn't exist at an accurate enough level to compete against generic supply-side resources, which are all evaluated on a comparable basis which excludes these costs (other than generic fixed and variable O&M). 2. Depends on the definition of "competing" and "full range," but yes, DSM resources are seen by the model and treated mathematically the same as supply-side resources. The difference lies in the start year relative to capacity need and the fact that DSM resources are evaluated based on net economic benefit and do not require a capacity need to be present in year 1 (2019). 3. In the capacity expansion phase the limit is 1,000 MWh per hour. In the production cost phase there is no explicit limitation. 4. In the capacity expansion phase the limit is 200 MWh per hour. In the production cost phase there is no explicit limitation. 5. Non-ELL resource additions in MISO are added to the market to meet a (16%) reserve margin and are added in the ratios listed in the future summary matrix (Table 12 of Section IV of this

	<p>Draft IRP).</p> <p>6. None</p> <p>7. DR resource profiles are generated by ICF using avoided cost inputs from ELL and ICF internal software / algorithms.</p>
<p>Sierra Club states that "it appears that Entergy is likely operating...[NL6] non-economically, or at a loss". Specifically, it appears as if they are "self-scheduling" "regardless of the market price". They go on to provide "estimated losses" for WB and ISES, but not for NL6. Page 3 of the "2018_0614 Sierra Club Comments" document.</p> <p>Sierra Club infers that ELL is "hard-wiring" NL6 "into the model" (AURORA). Pages 5 and 6 of the "2018_0614 Sierra Club Comments" document.</p>	<p>In the context of IRP modeling, Nelson 6 is modeled such that it is committed and dispatched based on economics. Nelson 6 typically operates at high utilization rates, which is indicative of a highly economic resource. Nelson 6 is not modeled as a Must Run unit or forced to operate on a set schedule regardless of economics.</p>
<p>Sierra Club recommends that ELL should use a non-zero CO2 price in all of its scenarios. Pages 6 to 13 of the "2018_0614 Sierra Club Comments" document.</p>	<p>As described in Section III of this Draft IRP, ELL has decided to model a zero CO2 price in one of its futures to represent either no carbon control program or a program that does not result in tradable CO2 prices. ELL believes that some kind of national carbon regulation will occur, and has modeled programs with non-zero CO2 prices in the other three futures.</p>
<p>Sierra Club recommends that in modeling, CO2 cost should influence the dispatch of Entergy's units, and not be treated as a cost "after the fact". Pages 6 to 13 of the "2018_0614 Sierra Club Comments" document.</p>	<p>The AURORA model dispatch takes into account CO2 prices when calculating economic dispatch.</p>
<p>Sierra Club recommends that ETR should be sure to not overly constrain the model including ensuring that it minimizes manual portfolio decisions and prescreening. Pages 13 to 16 of the "2018_0614 Sierra Club Comments" document.</p>	<p>ELL fully agrees and complies with this recommendation.</p>
<p>Sierra Club recommends that ETR should ensure that it captures avoided costs that are provided by certain resources that occur</p>	<p>Many avoided costs "outside of traditional energy planning" are site and/or project specific and are therefore not well suited for capacity</p>

<p>outside of traditional energy planning. Ideally, this would be done through an assessment of those value streams outside of the model structure (and subsequent repricing in the model). Pages 13 to 16 of the “2018_0614 Sierra Club Comments” document.</p>	<p>expansion optimization.</p>
<p>Sierra Club recommends that ETR should ensure that the model captures the energy shifting value of storage or demand response. Pages 13 to 16 of the “2018_0614 Sierra Club Comments” document.</p>	<p>Energy market benefits for storage and demand response are captured through the model's dispatch logic and DR load shape inputs, respectively.</p>
<p>Sierra Club recommends that all data should be provided at the first step of the stakeholder engagement process and be updated promptly throughout the process. Page 23 of the “2018_0614 Sierra Club Comments” document.</p>	<p>ELL will take this feedback into consideration when developing data assumptions associated with its next IRP cycle.</p>
<p>SWEA recommends that ELL should not “self-schedule” or “hard-wire” new or existing generating units to dispatch in its model run. Page 11 of the “2018_0614 SWEA Comments” document.</p> <p>SWEA recommends that ELL should report the results of these non-self-scheduled model runs and the implications for each of its existing generating units. Page 11 of the “2018_0614 SWEA Comments” document.</p>	<p>Except for nuclear, certain hydro, and solar resources that do not permit dispatch flexibility, all resources are modeled to economically commit and dispatch consistent with their capabilities.</p>
<p>SWEA recommends that ELL should explicitly verify that the AURORA software and its methodologies truly prioritize least-cost resources, and not prioritize capacity resources. Page 12 of the “2018_0614 SWEA Comments” document.</p> <p>Sierra Club recommends that ETR should ensure AURORA model has ability to fully optimize the ETR portfolio, including retirements and demand side resources. Pages 13 to 16 of the “2018_0614 Sierra Club</p>	<p>The AURORA model developed and used to perform evaluation of resource alternatives to meet ELL’s planning objectives in the IRP appropriately considers the cost and revenue of energy and capacity in the context of the MISO market.</p>

<p>Comments” document.</p>	
<p>SWEA recommends that ELL use the National Renewable Energy Lab’s (NREL’s) Annual Technology Baseline (ATB) as a resource for model inputs and future forecasts for IRP processes (this document, according to SWEA, is scheduled to be published in August, 2018). There are specific references to which data sets should be used. Pages 2 and 3 of the “2018_0614 SWEA Comments” document.</p> <p>SWEA recommends that ELL should use NREL’s ATB values, and verify that “inflation” does not artificially cause renewable energy prices to continually increase over time. Page 13 of the “2018_0614 SWEA Comments” document.</p>	<p>ELL considers several public and proprietary sources when developing the generating technology capital cost estimates included in the IRP modeling. The 2018 NREL ATB capital cost forecast values for solar and wind resources are similar to the inputs used for capacity expansion modeling when compared on an even basis (e.g. nominal \$/kW-AC). The treatment of cost inputs with respect to inflation has no effect on the results since all technologies are treated identically.</p>
<p>SWEA recommends that ELL should include PTC and ITC in near-term project procurement as cost reductions. Pages 7 and 8 of the “2018_0614 SWEA Comments” document.</p>	<p>The IRP is solving for a high-level indication of what types of capacity should be procured or investigated to meet ELL's long-term capacity need beginning in the mid-2020s. Accordingly, the PTC is assumed to have expired and the ITC is held constant at 10%.</p>
<p>SWEA recommends that ELL should evaluate low-cost energy purchases in its modeling, even if no capacity need exists. Page 12 of the “2018_0614 SWEA Comments” document.</p> <p>Sierra Club recommends that ETR should evaluate and incorporate low cost energy purchases and ensure its model prioritizes least-cost resources, even if no capacity is needed. Pages 17 to 20 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that ELL should allow market-based purchases in its modeling. Pages 17 to 20 of the “2018_0614 Sierra Club Comments” document.</p>	<p>Economic market-based energy purchases and prioritization of least-cost resources are accounted for in the IRP modeling to the extent ELL requires capacity to meet its planning objectives. However, ELL is forecasted to remain a net energy purchaser in the MISO market in the near future. Accordingly, additional economic energy purchases may be evaluated outside of the context of IRP modeling to support ELL’s planning objectives. Please see Section II and ELL’s Action Plan.</p>

<p>SWEA recommends that ELL should allow market-based purchases in its modeling. Page 12 of the “2018_0614 SWEA Comments” document.</p>	
---	--

Comments Regarding Portfolio Alternatives

<p>Sierra Club recommends that Entergy should ensure that its model can pick partial blocks of resources wherein block size is not a barrier (such as solar and wind) and pick reasonable partial blocks of other resources where capacity can be shared between utilities. Pages 13 to 16 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that ETR should develop a reasonable range of wind and solar resources alternatives using multiple variations of various technologies of different sizes and ensure that its model optimized decision-making by allowing it to choose partial blocks of resources, or combinations of resources. Pages 17 to 20 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that ETR should incorporate into its analysis the important co-benefits of battery storage. Pages 21 to 23 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that ETR should expand the options available and include additional battery store alternatives, including a two-hour option. Pages 21 to 23 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that ETR should</p>	<p>Solar, wind, and battery storage are evaluated as alternatives in the capacity expansion process of the IRP analysis. Resource alternatives are sized in the evaluation to be appropriate for meeting ELL's needs in the context of strategic IRP analysis. Specific resource sizing decisions are properly addressed in the detailed evaluations that are performed prior to selecting a resource. Coupling these resources would not improve the economics within the IRP evaluation of these alternatives. The nuanced benefits of coupling batteries and intermittent resources will continue to be explored on a case-by-case basis.</p>
---	--

<p>allow its modeling to select among portfolios of options including solar or wind coupled with batteries. Pages 21 to 23 of the “2018_0614 Sierra Club Comments” document.</p> <p>SWEA recommends that ELL should model blended renewable resources such as solar+wind, solar+storage, wind+storage, and wind+solar+storage as independent resources for possible selection. Page 13 of the “2018_0614 SWEA Comments” document.</p>	
<p>AAE urges ELL to use "up-to-date" advanced storage cost estimates and forecasts. Page 7 of the “Alliance Comments” document.</p>	<p>The storage cost forecast and estimates are as of October 2017 and predict aggressive cost declines.</p>
<p>AAE mentioned that the Company “did not make mention of Electric Vehicles”. Page 7 of the “Alliance Comments” document.</p>	<p>Please see the response in the “Electric Vehicle Assumptions” in the Data Assumptions Supplement filed June 1st 2018. .</p>
<p>Sierra Club recommends that ETR should clarify the sizing and specifications of the different resources like solar, wind, and battery options. Pages 13 to 16 of the “2018_0614 Sierra Club Comments” document.</p>	<p>Solar: 100MW Wind: 200MW Battery storage: 100MW/400MWh</p>
<p>Sierra Club recommends that ETR should include a cost projection for wind and solar resources that reflects current industry understanding and expectations. Pages 17 to 20 of the “2018_0614 Sierra Club Comments” document.</p>	<p>Cost projections included in the modeling and documented in the assumptions filing reflect current industry understanding and expectations. These have also been benchmarked against market data from RFPs and/or unsolicited offers.</p>
<p>Sierra Club urges ELL to adopt a transparent and robust resource planning framework that encourages the replacement of uneconomic fossil fuel resources with affordable renewable energy and energy efficiency investments. Page 2 of the “2018_0614 Sierra Club Comments” document.</p>	<p>See Section: Portfolio Results. The IRP reasonably evaluated all resource alternatives resulting in a wide range of the amount of renewable additions between the portfolios (1 GW (Portfolio 2) to 7.5 GW (Portfolio 4) on an installed capacity basis). Additionally, the evaluation resulted in over 550 MW of DSM in three out of the four portfolios.</p>

	See response above regarding deactivation assumptions and evaluations.
SWEA recommends that ELL should conduct a utility-scale energy storage study to develop several metrics for value stacking capability, in anticipation of full implementation of FERC Order Number 841 and conduct all modeling on a sub-hourly basis. Page 11 of the “2018_0614 SWEA Comments” document.	Energy storage is considered within ELL’s IRP evaluation. The evaluation indicates that further exploration of battery storage is warranted. Additional potential value streams and drivers will be considered in project-specific evaluations.
SWEA recommends that ELL should not include the modeling of tariffs on solar panels. Pages 8 and 9 of the “2018_0614 SWEA Comments” document.	The current cost assumptions do not include the solar PV module tariffs.
SWEA recommends that ELL issue an RFI regarding wind energy, solar energy, and energy storage to receive project specific pricing, performance, and locations and incorporate federal PTC and ITC for renewable energy resources, and some energy storage projects that are tied to renewable energy resources. Page 11 of the “2018_0614 SWEA Comments” document.	ELL asserts that pricing reflected in its data assumptions is reflective of market forecasts. An issuance of an RFI would be duplicative given that ELL is currently using industry standard resources to develop the data assumptions. Furthermore, ELL issued an RFP in 2016 specifically related to renewable resources. Through that effort ELL was able to obtain "project specific" information. Through the course of ELL's normal business, ELL will continue to evaluate whether or not it is appropriate to issue additional RFPs, which may include renewable resources, as business needs arise.
SWEA recommends that ELL evaluate both fixed-tilt and single-axis tracking PV. Page 10 of the “2018_0614 SWEA Comments” document.	The Technology Assessment fully addresses this.
SWEA recommends that ELL's modeling regarding renewable energy resources should reflect an anticipated decline in costs over time. Pages 6 and 7 of the “2018_0614 SWEA Comments” document.	The cost inputs to the model do reflect anticipated cost declines over time for renewable resources as well as energy storage.
SWEA recommends that ELL provide a comparison of capacity values for various wind energy and solar energy resources to that of ELL's peak load, MISO's peak load, and	ELL's assumed solar capacity credit and wind credit are based on the MISO Tariff. Please see Table 10: Renewable Modeling Assumptions and Section “Solar Capacity Credit Modeling”

<p>MISO's wind energy and solar energy capacity valuations. Page 10 of the “2018_0614 SWEA Comments” document.</p>	<p>for more information on assumptions used for solar and wind generation.</p>
<p>To the extent that ELL will require new energy generating resources in the next five years, ELL should consider accelerating the adoption of those resources to take full advantage of the expiring PTC and ITC. Page 10 of the “2018_0614 SWEA Comments” document.</p>	<p>ELL intends to procure generation resources consistent with its long-term planning objectives. Please see ELL’s Action Plan.</p>
<p>SWEA recommends that ELL should evaluate multiple energy storage configurations, using sub-hourly dispatch, with multiple revenue streams as stand-alone projects as well as coupled with generation resources. Pages 6 and 7 of the “2018_0614 SWEA Comments” document.</p> <p>AAE urges ELL to model battery storage on a sub-hourly basis. Page 6 of the “2018_0614 Alliance Comments” document.</p>	<p>While the AURORA model has the capability to simulate sub-hourly time intervals, the analysis is prohibitively time consuming considering the scope and strategic objectives of the IRP analyses.</p>
<p>AAE recommends that ELL use hourly and sub-hourly load shaped from NREL's WIND Toolkit and NREL's System Advisor Model (SAM). Page 9 of the “2018_0614 Alliance Comments” document.</p>	<p>NREL SAM is used for wind hourly profiles. As stated previously, the AURORA model is currently run using an hourly time resolution.</p>

Comments Regarding Scenarios, Sensitivities, and Risk

<p>Staff requests that ELL incorporate a probability weighting of the scenarios used and that the Company fully document the sensitivity and scenario analyses' data assumptions and results. This information is to be included in one or more technical appendices to the Draft IRP Report. Page 16 of the “2018_0614 Staff Comments” document.</p>	<p>An equal probability weighting per future is implicit within the framework of the risk assessment. See Section III: Assumptions and Section IV: Portfolio Design Analytics for more detail on the assumptions used, the analytical framework, and the results of the evaluation.</p>
<p>AAE recommends that ELL “evaluate</p>	<p>Current assumptions are a reasonable outlook</p>

<p>multiple tranches with different performance levels and pricing assumptions [which is] similar to analysis performed for fuel-based power generation resources.” To the extent possible, data should be used from the 2018 NREL ATB, when published in August. Page 9 of the “2018_0614 Alliance Comments” document.</p>	<p>of renewable development costs, and are based on an annual, confidential IHS forecast and market information. Meaningful sensitivities are incorporated within the futures and focus on inputs that impact ongoing market prices. To the extent development cost assumptions change, these costs would be incorporated through subsequent planning processes, IRPs, and procurement activities.</p>
<p>Sierra Club recommends that ETR should decouple commodity prices, emissions prices, and other assumptions. Choose the most important sensitivities and provide reasonable corner or end members of these sensitivities. Provide more than four optimization runs. Page 16 to 17 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that sensitivities for potential CO2 and other environmental compliance costs should be conducted independently of each other and other variables (i.e. not correlated). Page 6 to 13 of the “2018_0614 Sierra Club Comments” document.</p>	<p>The current futures framework is a comprehensive analysis which reasonably bookends possible outcomes including those around commodity and emissions prices. The futures were formulated with the intent that the assumptions present in each future are cohesive and logically sound.</p>
<p>Sierra Club recommends that ELL's reference case should model a cap reflecting the application of section 111(d) to both existing and new electric generating units. Page 6 to 13 of the “2018_0614 Sierra Club Comments” document.</p>	<p>Section 111(d) of the Clean Air Act applies only to existing units. A regulatory program similar to the Clean Power Plan, the current regulation interpreting 111(d), is included as the reference case of Entergy’s carbon pricing point of view and is included as an input to the futures described above. Section 111(b) regulations, which apply to new units, are considered as new units are planned and developed. CO2 prices assumed within the futures are applied to both existing and new generation within the AURORA model. See Section “CO2 Price Assumptions” for a more detailed description of the CO2 assumptions used.</p>

Other Comments

<p>LEUG urges that the LPSC should initiate proceedings to investigate its proposals for: 1) an industrial customer market access option, 2) a new interruptible service tariff option, 3) a real-time pricing tariff options, and 4) a market-based stand-by service option. Pages 1 to 8 of the “2018_0614 LEUG Comments” document.</p>	<p>Some of LEUG’s requests go beyond the scope of this IRP process and in fact run contrary to a primary purpose of this process, maintaining a reliable electric system for Louisiana customers. As discussed herein, the MISO capacity market is not designed to provide compensation for the full cost of generation resources. Rather, MISO relies on utilities within its market to provide the resources needed to ensure reliability through long-term resource planning under the regulation of state commissions. Therefore, allowing a select set of customers access to the pricing of the MISO market, rather than paying full retail rates, would allow those customers to avoid the full cost of the generation needed to reliably serve all Louisiana customers. The customers not offered that option would then be forced to pay for the total cost of generation or, alternatively, refuse to continue building needed generation for which they would receive an undue share of the costs. The result of the latter option is a lack of local generation needed to serve customers. This IRP process is intended to achieve the opposite result.</p> <p>That being said, the Company is willing to explore tariff options that do not result in the cost shifting noted above. For example, as part of its Action Plan, the Company has committed to designing and offering a new interruptible service tariff that would be generally available to customers, including LEUG members.</p>
<p>LEUG requests that Entergy, in its Draft IRP Report, "identify and describe" any RMR units that it operates and discuss any actions that could be taken to eliminate the RMR units. Page 9 of the “2018_0614 LEUG</p>	<p>Please see the Transmission Planning section of this Draft IRP for an explanation of why transmission alternatives are not modeled in this stage of ELL’s long-term planning. Proposed economic transmission solutions are reviewed as part of MISO's MTEP process as</p>

<p>Comments” document.</p>	<p>projects for approval when a business case can be established on the basis of benefits that are shown to exceed commensurate costs.</p>
<p>LEUG requests that Entergy, in its Draft IRP Report, "identify and describe" any significant transmission constraints and limitations within the system and discuss any actions that could be taken to eliminate the constraints, limitations. Page 10 of the “2018_0614 LEUG Comments” document.</p>	<p>Specific transmission constraints on the ELL system, both reliability and economic, along with proposed projects to mitigate them, are described in MISO's annual MTEP report, which is posted publicly at www.misoenergy.org/planning/transmission-studies-and-reports. These constraints and mitigations are analyzed through Entergy's LTTP and MISO's MCPS MTEP processes, as described in Section I: Transmission Planning of the draft IRP. Details of the Transmission Study processes are included in “Book 1,” and details of the ELL constraints and mitigation projects are included in “Appendix D1 (South).”</p>
<p>Sierra Club recommends that ELL should develop estimates for decommissioning and demolition of its units. These estimates should be open to vetting by the commission and stakeholders and should be presented in terms of net costs (the cost of decommissioning and demolition less the revenue generated from sale of scrap metal, salvaged equipment, and land value). Page 6 of the “2018_0614 Sierra Club Comments” document.</p>	<p>ELL suggests that this comment is not relevant to the IRP. As is stated in LPSC General Order R-30021, the purpose of the IRP is for the utility “to develop long-term resource plans, which include both supply and demand-side resources, and consider transmission needs, or order to satisfy the utility’s load requirements.” The costs of decommissioning and demolishing units would be the same (with except to CPI-related cost changes) regardless of when a unit is decommissioned and demolished.</p>
<p>Sierra Club recommends that ELL should present findings from a detailed financial analysis including the costs of compliance with the Regional Haze Rule, the Clean Air Act's New Source Review Program, the NAAQS for both SO₂ and ozone, the Clean Water Act's ELG rule, CCR Rule, and 316(b) rule, all proposed and emerging regulations. Pages 6 to 13 of the “2018_0614 Sierra Club Comments” document.</p> <p>Sierra Club recommends that ELL should include in its analysis sensitivities for compliance costs and the resulting effect on</p>	<p>Information concerning each of these rules other than the Clean Water Act Effluent Guidelines (“ELG’s”) is included in Entergy’s consolidated 2017 10K (pages 263-273). This can be accessed at http://www.entergy.com/investor_relations/2017_publications.aspx.</p> <p>Within the ELL fleet, the ELG regulations are expected to apply to ELL’s Nelson 6 coal unit and NRG’s Big Cajun. These regulations currently are under review by EPA. The cost</p>

<p>the fleet's operations. Page 6 to 13 of the “2018_0614 Sierra Club Comments” document.</p>	<p>of compliance with these regulations will depend on the final form of the rule.</p>
<p>API suggests that ETR look at system reliability from an attributes-oriented framework and recognizes the dynamic changes the company will encounter as energy demands and resource availability shifts. Page 2 to 5 of the “2018_0614 API Comments(2)” document.</p>	<p>Fuel diversity is not achieved for its own sake, but rather because it represents a reduction in commodity price risk which translates to lower production cost risk for ELL's customers. See Section: Assessment of Risks describing the risk assessment used in the IRP evaluation. See Section: Integration of Transmission and Resource Planning regarding the need to understand the requirements for inertial generation (e.g. CT, CCGT) on a high load factor system with many industrial customers.</p>

Appendix C Total Relevant Supply Costs - Detail

Future 1 – Present Value (2019\$) of Total Relevant Supply Costs

Note: Fixed costs are calculated on a levelized real basis for all futures

Portfolio 1 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$22,755
Resource Additions - Fixed Costs	[\$MM]	\$3,285
Capacity Purchases / (Sales)	[\$MM]	(\$226)
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$26,294

Portfolio 2 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$23,931
Resource Additions - Fixed Costs	[\$MM]	\$2,249
Capacity Purchases / (Sales)	[\$MM]	(\$128)
DSM - Fixed Costs	[\$MM]	\$482
Total Supply Cost	[\$MM]	\$26,534

Portfolio 3 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$23,194
Resource Additions - Fixed Costs	[\$MM]	\$2,677
Capacity Purchases / (Sales)	[\$MM]	\$206
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$26,557

Portfolio 4 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$22,043
Resource Additions - Fixed Costs	[\$MM]	\$5,396
Capacity Purchases / (Sales)	[\$MM]	(\$382)
DSM - Fixed Costs	[\$MM]	\$42
Total Supply Cost	[\$MM]	\$27,099

Future 1 – Annual Total Relevant Supply Costs

CE Portfolio 1																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,573	\$1,631	\$1,660	\$1,723	\$1,777	\$1,862	\$1,927	\$1,967	\$2,015	\$2,173	\$2,197	\$2,277	\$2,374	\$2,198	\$2,203	\$2,348	\$2,321	\$2,362	\$2,472	\$1,707
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$35	\$144	\$206	\$347	\$719	\$978	\$1,046	\$1,311	\$1,350	\$1,421	\$1,494	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$1	(\$0)	(\$1)	(\$1)	(\$1)	(\$4)	(\$8)	(\$19)	(\$9)	(\$4)	(\$15)	(\$19)	(\$43)	(\$59)	(\$69)	(\$81)	(\$88)	(\$92)	(\$92)
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$56	\$57	\$58	\$59	\$60	\$61	\$61
Total Supply Cost	[\$MM]	\$1,589	\$1,653	\$1,689	\$1,758	\$1,813	\$1,899	\$1,963	\$2,001	\$2,041	\$2,247	\$2,390	\$2,522	\$2,758	\$2,930	\$3,179	\$3,381	\$3,609	\$3,683	\$3,861	\$3,170
CE Portfolio 2																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,585	\$1,631	\$1,660	\$1,722	\$1,777	\$1,861	\$1,926	\$1,967	\$2,014	\$2,143	\$2,212	\$2,329	\$2,420	\$2,436	\$2,481	\$2,641	\$2,708	\$2,763	\$2,924	\$2,999
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$41	\$119	\$137	\$276	\$483	\$700	\$726	\$871	\$900	\$931	\$967	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$1	(\$0)	(\$1)	(\$1)	(\$1)	(\$4)	(\$8)	(\$19)	(\$20)	(\$15)	(\$17)	(\$19)	(\$23)	(\$27)	(\$29)	(\$33)	(\$37)	(\$42)	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$46	\$49	\$52	\$54	\$56	\$57	\$57	\$58	\$60	\$61	\$62	
Total Supply Cost	[\$MM]	\$1,601	\$1,653	\$1,689	\$1,757	\$1,813	\$1,899	\$1,962	\$2,001	\$2,040	\$2,213	\$2,368	\$2,503	\$2,735	\$2,956	\$3,214	\$3,397	\$3,607	\$3,689	\$3,878	\$3,986
CE Portfolio 3																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,573	\$1,631	\$1,660	\$1,723	\$1,777	\$1,862	\$1,927	\$1,967	\$2,015	\$2,176	\$2,252	\$2,374	\$2,472	\$2,453	\$2,316	\$2,441	\$2,226	\$2,259	\$2,390	\$2,436
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$47	\$185	\$411	\$770	\$827	\$1,275	\$1,312	\$1,351	\$1,423	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$1	(\$0)	(\$1)	(\$1)	(\$1)	(\$4)	(\$8)	(\$19)	(\$2)	\$37	\$54	\$58	\$67	\$63	\$59	\$54	\$52	\$54	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$56	\$57	\$58	\$59	\$60	\$61	
Total Supply Cost	[\$MM]	\$1,589	\$1,653	\$1,689	\$1,758	\$1,813	\$1,899	\$1,963	\$2,001	\$2,041	\$2,223	\$2,364	\$2,530	\$2,770	\$2,988	\$3,211	\$3,388	\$3,617	\$3,684	\$3,853	\$3,973
CE Portfolio 4																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,577	\$1,639	\$1,676	\$1,749	\$1,811	\$1,907	\$1,981	\$2,015	\$2,065	\$2,019	\$2,057	\$2,120	\$2,155	\$2,046	\$1,946	\$2,030	\$1,953	\$1,981	\$2,058	\$2,067
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$35	\$320	\$453	\$542	\$769	\$1,101	\$1,472	\$1,567	\$1,903	\$1,953	\$2,060	\$2,191	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$1	(\$0)	(\$1)	(\$1)	(\$1)	(\$3)	(\$6)	(\$13)	(\$39)	(\$58)	(\$60)	(\$63)	(\$66)	(\$86)	(\$104)	(\$110)	(\$114)	(\$123)	(\$129)
DSM - Fixed Costs	[\$MM]	\$3	\$3	\$3	\$3	\$3	\$3	\$3	\$4	\$4	\$4	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	
Total Supply Cost	[\$MM]	\$1,582	\$1,643	\$1,678	\$1,751	\$1,813	\$1,909	\$1,981	\$2,036	\$2,091	\$2,304	\$2,458	\$2,607	\$2,866	\$3,085	\$3,338	\$3,498	\$3,750	\$3,825	\$4,000	\$4,134

Future 2 – Present Value (2019\$) of Total Relevant Supply Costs

Portfolio 1 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$18,168
Resource Additions - Fixed Costs	[\$MM]	\$3,285
Capacity Purchases / (Sales)	[\$MM]	(\$117)
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$21,816

Portfolio 2 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$18,749
Resource Additions - Fixed Costs	[\$MM]	\$2,249
Capacity Purchases / (Sales)	[\$MM]	(\$20)
DSM - Fixed Costs	[\$MM]	\$482
Total Supply Cost	[\$MM]	\$21,460

Portfolio 3 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$18,315
Resource Additions - Fixed Costs	[\$MM]	\$2,677
Capacity Purchases / (Sales)	[\$MM]	\$315
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$21,787

Portfolio 4 - Total Relevant Supply Cost		
PV 2019\$ [2019-2038]		
Variable Supply Cost	[\$MM]	\$17,483
Resource Additions - Fixed Costs	[\$MM]	\$5,396
Capacity Purchases / (Sales)	[\$MM]	(\$273)
DSM - Fixed Costs	[\$MM]	\$42
Total Supply Cost	[\$MM]	\$22,647

Future 2 – Annual Total Relevant Supply Costs

CE Portfolio 1																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,478	\$1,474	\$1,462	\$1,463	\$1,518	\$1,575	\$1,617	\$1,653	\$1,664	\$1,720	\$1,733	\$1,748	\$1,736	\$1,490	\$1,460	\$1,557	\$1,489	\$1,455	\$1,526	\$1,524
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$35	\$144	\$206	\$347	\$719	\$978	\$1,046	\$1,311	\$1,350	\$1,421	\$1,494	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$1)	(\$1)	(\$3)	(\$4)	(\$7)	\$8	\$14	\$4	\$1	(\$22)	(\$37)	(\$46)	(\$57)	(\$64)	(\$67)	(\$67)	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$56	\$57	\$58	\$59	\$60	\$61	
Total Supply Cost	[\$MM]	\$1,493	\$1,496	\$1,491	\$1,498	\$1,554	\$1,612	\$1,654	\$1,691	\$1,702	\$1,812	\$1,944	\$2,012	\$2,140	\$2,244	\$2,458	\$2,613	\$2,801	\$2,800	\$2,939	\$3,012

CE Portfolio 2																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,478	\$1,473	\$1,462	\$1,463	\$1,518	\$1,575	\$1,618	\$1,651	\$1,663	\$1,698	\$1,730	\$1,764	\$1,744	\$1,658	\$1,657	\$1,760	\$1,744	\$1,714	\$1,811	\$1,814
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$41	\$119	\$137	\$276	\$483	\$700	\$726	\$871	\$900	\$931	\$967	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$1)	(\$1)	(\$3)	(\$4)	(\$7)	(\$3)	\$3	\$3	\$3	\$2	(\$1)	(\$4)	(\$6)	(\$9)	(\$13)	(\$17)	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$46	\$49	\$52	\$54	\$56	\$57	\$57	\$58	\$60	\$61	\$62	
Total Supply Cost	[\$MM]	\$1,494	\$1,495	\$1,491	\$1,498	\$1,554	\$1,613	\$1,655	\$1,689	\$1,701	\$1,785	\$1,904	\$1,958	\$2,080	\$2,200	\$2,412	\$2,539	\$2,667	\$2,664	\$2,789	\$2,825

CE Portfolio 3																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,478	\$1,474	\$1,462	\$1,463	\$1,518	\$1,575	\$1,617	\$1,653	\$1,664	\$1,723	\$1,776	\$1,824	\$1,814	\$1,701	\$1,526	\$1,607	\$1,409	\$1,381	\$1,464	\$1,475
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$47	\$185	\$411	\$770	\$827	\$1,275	\$1,312	\$1,351	\$1,423	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$1)	(\$1)	(\$3)	(\$4)	(\$7)	\$16	\$55	\$74	\$78	\$89	\$89	\$86	\$83	\$78	\$77	\$79	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$56	\$57	\$58	\$59	\$60	\$61	
Total Supply Cost	[\$MM]	\$1,493	\$1,496	\$1,491	\$1,498	\$1,554	\$1,612	\$1,654	\$1,691	\$1,702	\$1,787	\$1,907	\$1,999	\$2,133	\$2,257	\$2,442	\$2,577	\$2,824	\$2,831	\$2,951	\$3,037

CE Portfolio 4																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,480	\$1,480	\$1,474	\$1,483	\$1,548	\$1,612	\$1,662	\$1,691	\$1,705	\$1,602	\$1,617	\$1,612	\$1,553	\$1,370	\$1,272	\$1,326	\$1,230	\$1,194	\$1,243	\$1,239
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$35	\$320	\$453	\$542	\$769	\$1,101	\$1,472	\$1,567	\$1,903	\$1,953	\$2,060	\$2,191	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$0)	(\$1)	(\$1)	(\$2)	(\$1)	(\$0)	(\$22)	(\$39)	(\$41)	(\$43)	(\$45)	(\$64)	(\$81)	(\$86)	(\$90)	(\$99)	(\$104)
DSM - Fixed Costs	[\$MM]	\$3	\$3	\$3	\$3	\$3	\$3	\$3	\$4	\$4	\$4	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	
Total Supply Cost	[\$MM]	\$1,485	\$1,485	\$1,477	\$1,486	\$1,550	\$1,614	\$1,663	\$1,716	\$1,743	\$1,904	\$2,035	\$2,118	\$2,284	\$2,431	\$2,686	\$2,816	\$3,052	\$3,062	\$3,210	\$3,331

Future 3 – Present Value (2019\$) of Total Relevant Supply Costs

Portfolio 1- Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$18,991
Resource Additions - Fixed Costs	[\$MM]	\$3,285
Capacity Purchases / (Sales)	[\$MM]	(\$532)
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$22,224
Portfolio 2 - Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$20,196
Resource Additions - Fixed Costs	[\$MM]	\$2,249
Capacity Purchases / (Sales)	[\$MM]	(\$435)
DSM - Fixed Costs	[\$MM]	\$482
Total Supply Cost	[\$MM]	\$22,492
Portfolio 3 - Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$18,819
Resource Additions - Fixed Costs	[\$MM]	\$2,677
Capacity Purchases / (Sales)	[\$MM]	(\$100)
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$21,876
Portfolio 4 - Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$17,682
Resource Additions - Fixed Costs	[\$MM]	\$5,396
Capacity Purchases / (Sales)	[\$MM]	(\$688)
DSM - Fixed Costs	[\$MM]	\$42
Total Supply Cost	[\$MM]	\$22,431

Future 3 – Annual Total Relevant Supply Costs

CE Portfolio 1																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,411	\$1,383	\$1,359	\$1,353	\$1,383	\$1,426	\$1,445	\$1,461	\$1,456	\$2,018	\$2,066	\$2,102	\$2,109	\$1,783	\$1,699	\$2,018	\$1,813	\$1,843	\$2,163	\$2,182
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$35	\$144	\$206	\$347	\$719	\$978	\$1,046	\$1,311	\$1,350	\$1,421	\$1,494	
Capacity Purchases / (Sales)	[\$MM]	\$1	\$1	(\$1)	(\$1)	(\$2)	(\$7)	(\$19)	(\$52)	(\$56)	(\$54)	(\$68)	(\$74)	(\$101)	(\$121)	(\$134)	(\$149)	(\$159)	(\$167)	(\$171)	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$57	\$57	\$58	\$59	\$60	\$61	
Total Supply Cost	[\$MM]	\$1,425	\$1,404	\$1,388	\$1,387	\$1,419	\$1,462	\$1,478	\$1,484	\$1,450	\$2,045	\$2,208	\$2,295	\$2,437	\$2,457	\$2,613	\$2,987	\$3,033	\$3,093	\$3,477	\$3,566

CE Portfolio 2																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,411	\$1,383	\$1,359	\$1,353	\$1,383	\$1,426	\$1,445	\$1,461	\$1,456	\$1,989	\$2,067	\$2,127	\$2,099	\$2,042	\$2,091	\$2,433	\$2,343	\$2,451	\$2,766	\$2,841
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$41	\$119	\$137	\$276	\$483	\$700	\$726	\$871	\$900	\$931	\$967	
Capacity Purchases / (Sales)	[\$MM]	\$1	\$1	(\$1)	(\$1)	(\$2)	(\$7)	(\$19)	(\$52)	(\$67)	(\$65)	(\$69)	(\$72)	(\$77)	(\$85)	(\$91)	(\$97)	(\$105)	(\$113)	(\$121)	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$46	\$49	\$52	\$54	\$56	\$57	\$57	\$58	\$60	\$61	\$62	
Total Supply Cost	[\$MM]	\$1,425	\$1,404	\$1,388	\$1,387	\$1,419	\$1,463	\$1,478	\$1,485	\$1,449	\$2,012	\$2,173	\$2,249	\$2,359	\$2,504	\$2,763	\$3,125	\$3,174	\$3,306	\$3,644	\$3,749

CE Portfolio 3																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,411	\$1,383	\$1,359	\$1,353	\$1,383	\$1,426	\$1,445	\$1,461	\$1,456	\$2,023	\$2,124	\$2,204	\$2,224	\$2,053	\$1,760	\$1,979	\$1,467	\$1,543	\$1,851	\$1,799
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$47	\$185	\$411	\$770	\$827	\$1,275	\$1,312	\$1,351	\$1,423	
Capacity Purchases / (Sales)	[\$MM]	\$1	\$1	(\$1)	(\$1)	(\$2)	(\$7)	(\$19)	(\$52)	(\$49)	(\$13)	\$2	\$2	\$9	\$6	(\$1)	(\$9)	(\$17)	(\$23)	(\$25)	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$57	\$57	\$58	\$59	\$60	\$61	
Total Supply Cost	[\$MM]	\$1,425	\$1,404	\$1,388	\$1,387	\$1,419	\$1,462	\$1,478	\$1,484	\$1,450	\$2,023	\$2,186	\$2,307	\$2,467	\$2,530	\$2,593	\$2,861	\$2,791	\$2,897	\$3,239	\$3,258

CE Portfolio 4																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,413	\$1,390	\$1,373	\$1,372	\$1,411	\$1,461	\$1,487	\$1,498	\$1,497	\$1,907	\$1,922	\$1,931	\$1,824	\$1,560	\$1,292	\$1,557	\$1,181	\$1,290	\$1,778	\$1,702
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$35	\$320	\$453	\$542	\$769	\$1,101	\$1,472	\$1,567	\$1,903	\$1,953	\$2,060	\$2,191	
Capacity Purchases / (Sales)	[\$MM]	\$1	\$1	(\$1)	(\$1)	(\$1)	(\$2)	(\$6)	(\$16)	(\$45)	(\$86)	(\$107)	(\$113)	(\$118)	(\$125)	(\$147)	(\$169)	(\$178)	(\$186)	(\$198)	(\$208)
DSM - Fixed Costs	[\$MM]	\$3	\$3	\$3	\$3	\$3	\$3	\$3	\$4	\$4	\$4	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	
Total Supply Cost	[\$MM]	\$1,417	\$1,393	\$1,375	\$1,373	\$1,413	\$1,462	\$1,483	\$1,508	\$1,490	\$2,144	\$2,273	\$2,365	\$2,479	\$2,541	\$2,622	\$2,960	\$2,911	\$3,063	\$3,645	\$3,690


Future 4 – Present Value (2019\$) of Total Relevant Supply Costs

Portfolio 1 - Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$32,156
Resource Additions - Fixed Costs	[\$MM]	\$3,285
Capacity Purchases / (Sales)	[\$MM]	(\$117)
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$35,803
Portfolio 2 - Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$33,778
Resource Additions - Fixed Costs	[\$MM]	\$2,249
Capacity Purchases / (Sales)	[\$MM]	(\$20)
DSM - Fixed Costs	[\$MM]	\$482
Total Supply Cost	[\$MM]	\$36,489
Portfolio 3 - Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$32,400
Resource Additions - Fixed Costs	[\$MM]	\$2,677
Capacity Purchases / (Sales)	[\$MM]	\$315
DSM - Fixed Costs	[\$MM]	\$480
Total Supply Cost	[\$MM]	\$35,872
Portfolio 4 - Total Relevant Supply Cost		
		PV 2019\$ [2019-2038]
Variable Supply Cost	[\$MM]	\$30,603
Resource Additions - Fixed Costs	[\$MM]	\$5,396
Capacity Purchases / (Sales)	[\$MM]	(\$273)
DSM - Fixed Costs	[\$MM]	\$42
Total Supply Cost	[\$MM]	\$35,767


Future 4 – Annual Total Relevant Supply Costs

CE Portfolio 1																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,819	\$2,095	\$2,114	\$2,273	\$2,359	\$2,497	\$2,651	\$2,760	\$2,882	\$3,079	\$3,191	\$3,426	\$3,564	\$3,471	\$3,362	\$3,479	\$3,390	\$3,540	\$3,711	\$3,917
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$35	\$144	\$206	\$347	\$719	\$978	\$1,046	\$1,311	\$1,350	\$1,421	\$1,494	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$1)	(\$1)	(\$1)	(\$3)	(\$4)	(\$7)	\$8	\$14	\$4	\$1	(\$22)	(\$37)	(\$46)	(\$57)	(\$64)	(\$67)	(\$67)
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$56	\$57	\$58	\$59	\$60	\$60	\$61
Total Supply Cost	[\$MM]	\$1,834	\$2,117	\$2,143	\$2,308	\$2,395	\$2,534	\$2,689	\$2,799	\$2,921	\$3,170	\$3,401	\$3,690	\$3,968	\$4,225	\$4,359	\$4,535	\$4,702	\$4,885	\$5,125	\$5,404
CE Portfolio 2																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,819	\$2,095	\$2,117	\$2,274	\$2,361	\$2,504	\$2,646	\$2,762	\$2,883	\$3,085	\$3,205	\$3,482	\$3,603	\$3,854	\$3,830	\$4,006	\$4,083	\$4,283	\$4,536	\$4,723
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$41	\$119	\$137	\$276	\$483	\$700	\$726	\$871	\$900	\$931	\$967	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$1)	(\$1)	(\$1)	(\$3)	(\$4)	(\$7)	\$3	\$3	\$3	\$2	(\$1)	(\$4)	(\$6)	(\$9)	(\$13)	(\$17)	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$46	\$49	\$52	\$54	\$56	\$57	\$57	\$58	\$58	\$60	\$61	\$62
Total Supply Cost	[\$MM]	\$1,835	\$2,117	\$2,146	\$2,309	\$2,397	\$2,541	\$2,683	\$2,801	\$2,922	\$3,172	\$3,379	\$3,675	\$3,938	\$4,395	\$4,586	\$4,785	\$5,006	\$5,234	\$5,515	\$5,734
CE Portfolio 3																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,819	\$2,095	\$2,114	\$2,273	\$2,359	\$2,497	\$2,651	\$2,760	\$2,882	\$3,127	\$3,322	\$3,625	\$3,777	\$3,909	\$3,450	\$3,593	\$3,128	\$3,280	\$3,511	\$3,663
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$47	\$185	\$411	\$770	\$827	\$1,275	\$1,312	\$1,351	\$1,423	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$1)	(\$1)	(\$3)	(\$4)	(\$7)	\$16	\$55	\$74	\$78	\$89	\$89	\$86	\$83	\$78	\$77	\$79	
DSM - Fixed Costs	[\$MM]	\$13	\$20	\$29	\$36	\$37	\$38	\$40	\$43	\$45	\$49	\$52	\$54	\$56	\$56	\$57	\$58	\$58	\$60	\$60	\$61
Total Supply Cost	[\$MM]	\$1,834	\$2,117	\$2,143	\$2,308	\$2,395	\$2,534	\$2,689	\$2,799	\$2,921	\$3,191	\$3,452	\$3,800	\$4,096	\$4,466	\$4,367	\$4,563	\$4,543	\$4,730	\$4,998	\$5,226
CE Portfolio 4																					
	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029	2030	2031	2032	2033	2034	2035	2036	2037	2038	
Variable Supply Cost	[\$MM]	\$1,820	\$2,102	\$2,134	\$2,310	\$2,404	\$2,563	\$2,738	\$2,834	\$2,954	\$2,881	\$2,961	\$3,144	\$3,151	\$3,053	\$2,831	\$2,993	\$2,794	\$2,974	\$3,261	\$3,423
Resource Additions - Fixed Cos	[\$MM]	\$0	\$0	\$0	\$0	\$0	\$0	\$23	\$35	\$320	\$453	\$542	\$769	\$1,101	\$1,472	\$1,567	\$1,903	\$1,953	\$2,060	\$2,191	
Capacity Purchases / (Sales)	[\$MM]	\$2	\$2	(\$0)	(\$0)	(\$1)	(\$1)	(\$2)	(\$1)	(\$0)	(\$22)	(\$39)	(\$41)	(\$43)	(\$45)	(\$64)	(\$81)	(\$86)	(\$90)	(\$99)	(\$104)
DSM - Fixed Costs	[\$MM]	\$3	\$3	\$3	\$3	\$3	\$3	\$3	\$4	\$4	\$4	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5	\$5
Total Supply Cost	[\$MM]	\$1,825	\$2,107	\$2,136	\$2,313	\$2,406	\$2,565	\$2,739	\$2,859	\$2,992	\$3,183	\$3,379	\$3,649	\$3,882	\$4,113	\$4,244	\$4,484	\$4,615	\$4,842	\$5,227	\$5,515

Appendix D Financing Assumptions



Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan



Appendix E DSM Program Selections by Portfolio

Energy Efficiency		Portfolio 1	Portfolio 2	Portfolio 3	Portfolio 4
EE Industrial Sector	Industrial Process	x	x	x	
	Industrial Prescriptive & Custom	x	x	x	x
	Industrial Strategic Energy Management				
EE Residential Sector	Appliances Recycling	x	x	x	
	ENERGY STAR New Homes2	x	x	x	
	Home Audit and Retrofit	x	x	x	
	Residential Prescriptive Non-Lighting	x	x	x	
	Residential AC Tune up	x	x	x	
	Residential HVAC Duct Sealing	x	x	x	
	Residential Lighting	x	x	x	x
	Low Income Weatherization	x	x	x	x
	Residential Unitary AC and HP	x	x	x	
	Home Energy Use Benchmarking	x	x	x	
EE Commercial Sector	Commercial Prescriptive & Custom HVAC	x	x	x	
	Commercial Prescriptive & Custom Other				
	Small Business Solutions	x	x	x	
	RetroCommissioning				
	Commercial New Construction				
	Current Commercial Prescriptive & Custom Lighting	x	x	x	
	Reduced Commercial Prescriptive & Custom Lighting				
	Midstream Commercial Lighting				
	Max Potential EE MWs*	404	404	404	10

Entergy Louisiana, Inc. 2019 Draft Integrated Resource Plan

Demand Response		Portfolio 1	Portfolio 2	Portfolio 3	Portfolio 4
Reference Case	Residential DLC (thermostat + water heater)				
	Residential ToU				
	Commercial DLC (thermostat)				
	Commercial ToU				x
	Industrial ToU				
	Max Potential MWs*	0	0	0	13
High Case	Residential DLC (thermostat + water heater)	x	x	x	
	Residential ToU				
	Commercial DLC (thermostat)	x	x	x	x
	Commercial ToU		x		
	Industrial ToU				
	Max Potential DR MWs*	90	114	90	23
Combined DR & EE	Total Max Potential DSM MWs**	495	518	495	47

*MWs not grossed up for 12% Reserve margin

**Max Potential MW represents total MW DSM capacity in the year which DSM contributes the most capacity during the planning period. DSM capacity contribution will vary by year